



QUESTIONS & RÉPONSES No.2 QUESTIONS & ANSWERS

Dossier No – File No

5P300-15-5029/A

Projet - Project

Major Rehabilitation of Road 132 in Forillon National Park
Phase II

Date limite au plus tard -
Closing Date on or before
Wednesday, May 6, 2015 à 2:00
PM (EDT)

Date d'émission – Date of issue
May 1, 2015

OBJET DE LA PRÉSENTE MODIFICATION – THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING

The following questions (3) were asked by entrepreneurs. For your information, here are the questions and the answers.

Q1: IS THE HORIZONTAL JOINT OF CASTING IN THE ABUTMENT IS MANDATORY?

A1: The joint of poured is planned considering the deadlines for the realization of the works in the stream, that is September 16th (see art. 1.10.16 of the section 01 35 43). However, if all the works in the stream can be ended before September 16th, 2015, and it without making of joint of poured, then the latter will not be required.

Q2: STEEL DRAINS (4) OF THE DECK DO NOT APPEAR IN the schedule of submission. WHAT IS THE METHOD OF PAYMENT?

A2: This answer was provided in the amendment 1.

Q3: DURING A PROVINCIAL bid FOR AN EQUIVALENT STRUCTURE OF BRIDGE, THE TENDERER MUST BE ACCREDITED BY THE MTQ UNDER THE NAMING «STRUCTURES complexes ". does THE FEDERAL organization PARKS CANADA RESTRICT THE ACCESS TO the MARKET BY AN EQUIVALENT REQUIREMENT OR THE LICENSES OF THE STATE CONTROL OVER régie du bâtiment du Québec AND by RESPECTing THE CURRENT LAWS?

R3: The accreditation « structures complexes » by MTQ is not required is this project.

TOUTES LES AUTRES CONDITIONS INCLUSES DANS LES INSTRUCTIONS DE TRAVAIL DEMEURENT LES MÊMES / ALL OTHER CONDITIONS INCLUDED IN THE WORK INSTRUCTIONS REMAIN THE SAME.

Par la présente nous reconnaissons avoir reçu la version modifiée des instructions et nous attestons avoir modifié notre soumission en conséquence.

We hereby acknowledge receipt of the amendment instructions and confirm that provisions therefore have been made in our tender.

Pour être prise en considération, toute soumission devra être accompagnée d'un exemplaire signé de la présente modification. Si votre soumission a déjà été envoyée, veuillez signer et envoyer cette modification par télécopieur/courriel avec toutes révisions faites à votre prix de soumission, à nos bureaux avant la date limite. Télécopieur: 418-648-5392

Signed copy of this amendment must accompany each tender in order that the tender be considered. If your submission has already been sent, please sign and send this amendment by fax / email with any revisions made to your bid price, at our office before the deadline. Fax: 418-648-5392.

Signé - Signed	Titre - Title	Date
		