

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Sand Shed Replacement	
Solicitation No. - N° de l'invitation EZ899-152420/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2015-05-06
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-7504	
File No. - N° de dossier PWY-4-37362 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-05-12	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 666-9835 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: TC - Sandspit Airport - Sandsport, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-152420/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-4-37362

Buyer ID - Id de l'acheteur

pw025

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Please find Addendum No. 2 attached.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend/revise the Standard Contract Documents as follows:

QUESTIONS FROM BIDDERS:

Q: *If the footprint and building dimensions are maintained will alternate designs for the foundations be considered without first submitting a proposal to match the provided drawings?*

A: The foundation designs included in the Tender Documents are intended to be indicative in nature and are expected to be revised to suit the metal building system solution proposed by Bidders. Alternate foundation designs will be considered provided they meet all required design criteria in the Specifications.

(Note: PWGSC tendering policies forbid the use of Alternate Prices.)

Q: We would like to show the advantages in price and performance gained by using a sectional overhead door instead of the specified coiling door.

A: Tenders should be based on the specified overhead coiling doors. Alternate solutions will be discussed with the successful bidder following award of contract.

Q *Is there a drawing of the existing site services? Location, size, type, etc?*

A: There does not appear to be an accurate drawing showing all site services. A Schematic Electrical Site Plan can be made available but there is no assurance that services are located as shown on the drawing.

Q: *Drawing 3 on A2 - Storage Shelving Elevation – What size are the horizontal beams?*

A: Horizontal beams are to be 200 x 200 timber.

Q: *Who is responsible for removing and storing the current contents of the building?*

A: The building contents will be removed prior to turn over of site to Contractor.

End of Addendum No. 02