



Plotted: March 09, 2015, 10:57:49  
Filename: N:\Proj\2511-00485-00 Snowshed Burken\10.0 DRAWINGS\10.5 Structural\10.5.2 Sheet\100485-STRC-004.dwg\$B04



#### NOTES:

1. CONCRETE SHALL BE IN ACCORDANCE WITH CSA A23.1/2, CLASS C2 AND 32 MPa AT 28 DAYS.
2. REINFORCING STEEL COVER SHALL BE 50mm AND 75mm FOR CONCRETE CAST AGAINST GROUND.
3. ALL EXPOSED CONCRETE CORNERS SHALL BE CHAMFERED 20mm.
4. REINFORCING STEEL SHALL BE REGULAR UNCOATED STEEL, GRADE 400R AND IN ACCORDANCE WITH CSA G30.18.
5. THE SUB-BASE SHALL BE UNDISTURBED AND COMPETENT MATERIAL APPROVED BY THE MINISTRY REPRESENTATIVE.
6. GRANULAR BASE SHALL BE COMPACTED TO MINIMUM 95% SPD IN ACCORDANCE WITH ASTM D698.
7. ALL DIMENSIONS ARE IN mm UNLESS NOTED OTHERWISE.

THIS DRAWING AND DESIGN SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY CONSULTING SERVICES LTD. McELHANNEY CONSULTING SERVICES LTD. WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

INFORMATION ON EXISTING UTILITIES MAY NOT BE COMPLETE OR ACCURATE. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING UTILITIES AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.


THIS DRAWING HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES. McELHANNEY CONSULTING SERVICES LTD., ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS ACCEPT NO RESPONSIBILITY TO ANY OTHER PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, FOR LOSS OR LIABILITY INCURRED AS A RESULT OF THEIR USE OF THESE DRAWINGS.

B	03-09-15	ISSUED FOR TENDER	MC	MF
A	02-24-15	ISSUED FOR REVIEW	KDW	MF

No.	Date/Date	Description/Description	Drawn by Dessiné par	Approved Approuvé
-----	-----------	-------------------------	-------------------------	----------------------

Revision / Revision			
A	detail number numéro de détail	A	
B	source drawing no. de dessin no.	B	C
C	detail on drawing no. détail sur dessin no.		

Consultant's Stamp Sceau de l'expert-conseil	Eng. Stamp Sceau de l'ingénieur
---	------------------------------------

Client/client	
 Parks Canada Agency Western and Northern Region	L'Agence Parcs Canada Ouest et Nord Région

Consultant's Name Nom de l'expert-conseil
 <b>McElhanney</b>

Project Title/Titre du projet
ROGERS PASS SNOWSHED LIGHTING TRANS CANADA HIGHWAY THROUGH ROGERS PASS  GLACIER NATIONAL PARK, B.C.

Drawing title/Titre du dessin
SUBSTATION FOUNDATION SLAB

Surveyed by/Arpenté par	Drawn by/Dessiné par	Date/Date
	KDW	MAR. 09, 2015
Designed by/Concept par	Reviewed by/Revisé par	Scale/Echelle
MF	NJ	AS NOTED
Parks Canada Project Manager/Administrateur de Projets Parcs Canada		
Client Acceptance/Acceptation du client		Approved by/Approuvé par
Parks Canada Responsible Officer/Agent Responsable Parcs Canada		Parks Canada Project Manager/Administrateur de Projets Parcs Canada
Project No./No. du projet	Asset No./No. du bien	Sheet No./ No. de la feuille
201422		S01
Drawing Reference No./No. de référence du dessin		
G2002R1		