



**Royal Canadian Mounted Police  
Gendarmerie royale du Canada**

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A:  
Bid Receiving/Réception des soumissions**

**RCMP / GRC  
Purchasing Office - Bureau des achats:  
Procurement & Contracting Services/  
Service des acquisitions et des marchés  
5th Floor Bid Receiving Unit  
10065 Jasper Avenue NW  
Edmonton, AB T5J 3B1**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

**Proposal to: Royal Canadian Mounted Police**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

**Proposition aux: Gendarmerie royale du Canada**  
Nous offrons par la présente de vendre à Sa Majesté l'Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

**Comments – Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de  
l'entrepreneur**

**Facsimile No. - No de télécopieur:**

**Telephone No. - no de téléphone:**

**Issuing Office - Bureau de distribution**

Procurement & Contracting Services/  
Service des acquisitions et des marchés  
5th Floor Bid Receiving Unit  
10065 Jasper Avenue NW  
Edmonton, AB T5J 3B1  
Edmonton, AB T5J 3B1

<b>Title-Sujet:</b> Building Upgrades on RCMP Employee Housing Units located in Cross Lake, MB	
<b>Solicitation No. - No. de l'invitation</b> M5000-6-0071/A	<b>Date</b> May 14 <sup>th</sup> , 2015
Amendment No. – No modif : 001	
<b>Solicitation Closes -L=invitation prend fin</b> <b>at - à 2 :00 Mountain Daylight Savings Time</b> <b>Zone</b> <b>on - le May 26<sup>th</sup>, 2015</b>	
<b>F.O.B. - F.A.B.</b> Plant - Usine: Destination:√ Other-Autre:	
<b>Address Enquiries to: - Adresser toutes questions à:</b>  <b>Cyndi Ryan, Senior Contracting Officer</b> <a href="mailto:Cyndi.ryan@rcmp-grc.gc.ca">Cyndi.ryan@rcmp-grc.gc.ca</a>	
<b>Telephone No. - No de téléphone</b> 780-670-8624	<b>Fax No. - N° de FAX:</b> 780-454-4523
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> RCMP Employee Housing Units Cross Lake, MB	
This document contains a Personnel Security Requirement	
<b>Delivery Required - Livraison exigée:</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>	
_____	
Name /Nom	Title/Titre
_____	
Signature /Signature	Date/Jour
(Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.)	



**Amendment 001 has been raised to address a question being posed by a potential bidder.**

**Question:**

Would the consultant consider using Hardie Plank versus CanExel.

Some of the qualities of Hardie Plank it has a 15 year warranty on the finish , it is a cement type siding product whereas canexel is a fibre/plastic composition which will swell when moisture present.

**Response:**

The Consultant at Architecture 49 indicated that he would be fine with James Hardie products as a substitution to the products that were specified. His only concern is that Hardie Plank is 5/16" (8mm) thick vs the 13 mm thickness specified, therefore the Consultant recommends that the Contractor be informed that it is their responsibility to make any adjustments to the details to accommodate the thinner plank. The Contractor will also be responsible to meet the requirements of the specifications and drawings with this product as well.

**All other terms and conditions to remain the same.**