

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Travaux publics et Services gouvernementaux
Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7 ième étage
Montréal
Québec
H5A 1L6

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7 ième étage
Montréal
Québec
H5A 1L6

Title - Sujet Extension RMHC Archambault	
Solicitation No. - N° de l'invitation EF236-152430/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.064010.800	Date 2015-05-15
GETS Reference No. - N° de référence de SEAG PW-\$MTC-250-13208	
File No. - N° de dossier MTC-4-37400 (250)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-06-09	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cyr, Nicolas	Buyer Id - Id de l'acheteur mtc250
Telephone No. - N° de téléphone (514) 496-3389 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Établissement Archambault 242 Montée Gagnon Ste-Anne-des-Plaines QC J0N 1H0	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EF236-152430/A

Client Ref. No. - N° de réf. du client

R.064010.800

Amd. No. - N° de la modif.

004

File No. - N° du dossier

MTC-4-37400

Buyer ID - Id de l'acheteur

mtc250

CCC No./N° CCC - FMS No/ N° VME

THIS INVITATION TO TENDER IS, HEREBY, MODIFIED AS FOLLOW

SI04 OPTIONAL SITE VISIT

Delete:

There will be a site visit on May 21, 2015 at 1:30 pm. Interested bidders are to meet at the entrance of the Archambault Institution at 242 Montée Gagnon in Ste-Anne-des-Plaines, J0N 1H0

Insert:

There will be a site visit on May 21, 2015 at 1:30 pm. Interested bidders are to meet at the entrance of **Building A-2** of the Archambault Institution at 242 Montée Gagnon in Ste-Anne-des-Plaines, J0N 1H0. **See attached map.**

See questions and answers to this day in attached document

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

RECEIVED QUESTIONS :

Q1 : We noticed that there is a crawlspace of approximately 3' between the bottom of the structural slab and the top of the pile. However, there is no opening nor access to the crawlspace. When putting the formwork for the crawlspace, we are wondering how we will retrieve our equipment from the crawlspace. Will there be an access from the existing building?

A: There is no crawl space in the extension. It is a structural slab on grade.

Q2: Section 05 50 00 article 2.9.3 of the specifications mentions a "tubular section of 44mm x 44mm which can freely rotate around the steel rod", it seems as though the steel rod should be the one that is free within the section?

A: That is correct, to be clarified in addendum.

Q3: Should assembly be performed following galvanisation? The 25mm rod could potentially remain fixed following the galvanisation process.

A: In addition to the previous question, galvanisation must be performed following assembly. The interior rod must be galvanised beforehand.

Q4: The galvanisation process requires holes (+/- 2 holes per piece), are we to plug these holes after galvanisation?

A : If apparent, yes.

Q5: What are the thicknesses for the requested profiles (HSS44x44mm et HSS65x40mm)?

A: 3mm minimum, to be clarified in addendum.

Q6: Should we plan for a two-step installation, first attaching the frame to the masonry followed by the installation of the bar? Or is it possible to perform the work in a single step.

A: Two-step, to be clarified in addendum.

Q7: On some projects with security bars, the 25mm rod undergoes a treatment to increase its hardness. It does not seem to be the case in the current project, please confirm.

A: The resistance to cutting, the assaults, impact and deflection must comply with ASTM A627. To be clarified in addendum.

Q8: Page S04 refers to a temporary retaining wall. We are asked to install barbed wire at the top of said wall. It is our understanding that this wall is not connected to any other wall and/or fence, and as such do not see the usefulness of the barbed wire. Could you clarify?

A: The temporary retaining wall is continuous with the temporary construction site fence as outlined in the architecture documents.

Q9: Apart from construction workers, will there be other people accessing the work site? Are we required to plan for site fencing to secure the work area?

A: Yes, please refer to available documents.

Yes, temporary and permanent fencing are planned in civil and architecture documents. The construction site must be fully secure before beginning of work.