



**Royal Canadian Mounted Police
Gendarmerie royale du Canada**

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des soumissions**

**RCMP / GRC
Purchasing Office - Bureau des achats:
Procurement & Contracting Services/
Service des acquisitions et des marchés
5th Floor Bid Receiving Unit
10065 Jasper Avenue NW
Edmonton, AB T5J 3B1**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

Proposal to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

Proposition aux: Gendarmerie royale du Canada
Nous offrons par la présente de vendre à Sa Majesté l'Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de
l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Issuing Office - Bureau de distribution

Procurement & Contracting Services/
Service des acquisitions et des marchés
5th Floor Bid Receiving Unit
10065 Jasper Avenue NW
Edmonton, AB T5J 3B1
Edmonton, AB T5J 3B1

Title-Sujet: Building Upgrades on RCMP Employee Housing Units located in Cross Lake, MB	
Solicitation No. - No. de l'invitation M5000-6-0071/A	Date May 20 th , 2015
Amendment No. – No modif : 002	
Solicitation Closes -L=invitation prend fin at - à 2 :00 Mountain Daylight Savings Time Zone on - le May 26th, 2015	
F.O.B. - F.A.B. Plant - Usine: Destination:√ Other-Autre:	
Address Enquiries to: - Adresser toutes questions à: Cyndi Ryan, Senior Contracting Officer Cyndi.ryan@rcmp-grc.gc.ca	
Telephone No. - No de téléphone 780-670-8624	Fax No. - N° de FAX: 780-454-4523
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: RCMP Employee Housing Units Cross Lake, MB	
This document contains a Personnel Security Requirement	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	

Name /Nom	Title/Titre

Signature /Signature	Date/Jour
(Please sign and return cover page with bid proposal./ Signez s'il vous plaît et la page de couverture de retour avec la proposition d'offre.)	



Amendment 002 has been raised to address a question being posed by a potential bidder.

Question:

Can you please confirm that the strapping for the wall is 19 mm thick and the type 3 styrofoam being applied to the wall is 25 mm thick?

Response:

The Consultant at Architecture 49 has confirmed that the exterior wall as per drawing A301 Exterior Assemblies is a 19 x 64 vertical wood strapping @ 400 OC 25 mm board insulation, RSI 1.76.

All other terms and conditions to remain the same.