



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (403) 292-4475**

**INVITATION TO TENDER**

**APPEL D'OFFRES**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 - 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Snowshed LED Lighting Installation Glacier National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-15-5064/A	<b>Date:</b> May 21, 2015	
<b>GETS Reference No. - No de reference de SEAG</b> PW-15-00682098	<b>Amendment No. - N° de la modif.</b> 001	
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> May 28, 2015	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Nathaniel Pahl		
<b>Telephone No. - No de téléphone</b> (403) 292-4572	<b>Fax No. - No de FAX:</b> (403) 292-4475	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **Amendment 1**

This amendment is issued to answer questions from a potential bidder.

- Q1.** In the specifications, Reference 26 59 19, Sections 2.5.4 and 2.5.10.1, please describe the type of photocell control location and behavior.
- A1.** The Contractor is to design a control system that controls operation of the tunnel lighting such that luminaires operate in a daytime and nighttime mode based on the input from a photocell and internal astronomical timeclock control. The photocell provides an additional element of control beyond the time of day.
- Q2.** In the specifications, Reference 26 59 19, Sections 2.5.1.4 please provide detail of possible communication type between adjacent snowshed lighting controllers and any specific requirements regarding the Ethernet switch within the Lighting Control Cabinet.
- A2.** The communications system between snowshed and the maintenance yard is intended to be a future implementation. The Contractor must provide Industrial Ethernet switch to connect to the fibre cable.

**All other terms and conditions remain unchanged.**