

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Réception des soumissions - TPSGC / Bid Receiving
- PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
TPSGC/PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet PIERRE RADISSON - REFRIGERATION	
Solicitation No. - N° de l'invitation F3019-14N719/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F3019-14N719	Date 2015-05-25
GETS Reference No. - N° de référence de SEAG PW-\$QCL-037-16394	
File No. - N° de dossier QCL-4-37316 (037)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-05-29	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Woods, Michael	Buyer Id - Id de l'acheteur qcl037
Telephone No. - N° de téléphone (418) 649-2715 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F3019-14N719/A

Client Ref. No. - N° de réf. du client

F3019-14N719

Amd. No. - N° de la modif.

005

File No. - N° du dossier

QCL-4-37316

Buyer ID - Id de l'acheteur

qc1037

CCC No./N° CCC - FMS No/ N° VME

See next pages.

Solicitation No – N° de l'invitation
F3019-14N719/A
Client Ref No. – N° de réf. du client
F3019-14N719

Amd. No. – N° de la modif.
005
File No. – N° du dossier
QCL-4-37316

Buyer ID – id de l'acheteur
qcl 037

Please amend the above mentioned bidding solicitation with the changes below in relation to the questions and comments in suspense.

Questions and Answers:

Question 8:

Do all the drains on the evaporators need to be replaced or could they be reused?

Answer 8:

All drains need to be changed.

Question 9:

Do all the drains need to be heated or only the drains in the rooms that are bellow 0 deg. Celcius?

Answer 9:

All drains that have temperatures below zero have to be heated.

Question 10:

Can 240V and 440V power be used for the evaporators or 120V only?

Answer 10:

Both 120V and 240V are acceptable. The bidders shall include in their price any electrically power modifications required that are required for the modernized system (breaker, wiring).

Question 11:

A touch sensitive control panel is required with an easy to use interface with HDMI colours. Do you want HDMI colours or an HMI panel?

Answer 11:

There is a mistake in the specs. The following should be read: Touch sensitive, color HMI with easy to use comprehensive software is requested for the control panel.

Question 12:

Does the ship's alarm system "GE Fanuc CIMPLICITY" already have drivers to interact with Allen-Bradley products?

Answer 12:

There are possibilities using a converter. We prefer to remain with the actual communication system as fitted onboard.

Question 13:

Does the ship's alarm system "GE Fanuc CIMPLICITY" have Ethernet capabilities?

Solicitation No – N° de l'invitation
F3019-14N719/A
Client Ref No. – N° de réf. du client
F3019-14N719

Amd. No. – N° de la modif.
005
File No. – N° du dossier
QCL-4-37316

Buyer ID – id de l'acheteur
qcl 037

Answer 13:

The present communications" GE Fanuc CIMPLICITY" are by ETHERNET, TCP/IP connection.

Question 14:

Is freight required to be included in the overall price of the system? There is no indication of this in Appendix 1 of Annex 1.

Answer 14:

Yes, freight is to be included in the overall price of the system.

All other clauses and conditions from the bidding solicitation remain the same.