

Light Tower Refurbishment 2015
Cape Race, NL
F6879-151006

May 28, 2015

Page 1 of 1

ADDENDUM 1

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS

1. Contractor is advised that work on the interior of the tower will be on-going under a separate contract. Contractor to ensure that work activities (hoarding, scaffolding, etc.), do not impede access to the interior of the tower. Coordinate all work with the Departmental Representative.
2. On the drawing number 01K1101A051C2, Detail 1 (shed/porch upgrades), **ADD** the following requirement:
 - Remove the existing roof sheathing and replace with new treated timber plywood sheathing (19mm thickness), prior to placement of new shingles. Note that lead paint is present on the existing sheathing and the paint has not been tested for lead content. For Bidding purposes, assume the paint and substrate contain leachable lead exceeding landfill disposal guidelines, and in this regard, the paint and substrate are to be considered hazardous for the purposes of transportation and disposal.