

- GENERAL NOTES:
1. ALL MEASUREMENTS MUST BE VALIDATED ON SITE BY THE CONTRACTOR.
  2. ALL WELDS MUST BE MADE BY A COMPANY CERTIFIED BY THE CANADIAN WELDING BUREAU IN COMPLIANCE TO THE STANDARD W59. THE WELDERS AND THE FIRM WILL ALSO BE IN COMPLIANCE WITH THE W47.1 STANDARD.
  3. ALL THE USED STEELS WILL BE IN COMPLIANCE WITH THE CAN/CSA-G40.21 STANDARD, GRADE 300W FOR SHEETS AND GRADE 350W FOR OPEN PROFILES AND TUBES.
  4. BOLTED CONNECTIONS WILL BE IN STAINLESS STEEL.
  5. ALL STRUCTURES EXPOSED TO WEATHER WILL BE HOT DIPPED GALVANIZED WITH A ZINC COAT OF 600 G/M<sup>2</sup> IN COMPLIANCE WITH CAN/CSA-G104 STANDARD.

-	-	-
-	-	-
15 03 27	ISSUED FOR TENDER	M.W.
Y   M   D	MODIFICATION	BY
-- -- --	ISSUE DATE	--

CLIENT:  
**CIMAISE - AGENCE SPATIALE**

PROJECT:  
**#2015-014 - ROOF REFLECTION C-D-E-F**


TITLE:  
**ANCHORS LOCATION**

150 CHEMIN DES GRANITES  
LAC BEAUFORT, G3B 0G3  
TEL.: 418-849-9987, SANS FRAIS: 1-888-949-9987  
FAX: 418-849-6143, SANS FRAIS: 1-888-949-6143  
CELL.: 418-278-8987  
COURRIEL: JMASSE@SLM.ORG


**SERVICE D'INGÉNIERIE JEAN MASSÉ**

REF. CLIENT:	-	DATE:	2015-03-27
PROJECT:	#2015-014	PAGE:	
SCALE:	IND.		
SIZE:	ARCH D (24" X 36")		


INSTALLATION TYPE 1



INSTALLATION TYPE 2




INSTALLATION TYPE 3




- GENERAL NOTES:
- ALL MEASUREMENTS MUST BE VALIDATED ON SITE BY THE CONTRACTOR.
  - ALL WELDS MUST BE MADE BY A COMPANY CERTIFIED BY THE CANADIAN WELDING BUREAU IN COMPLIANCE WITH THE STANDARD W59. THE WELDERS AND THE FIRM WILL ALSO BE IN COMPLIANCE TO THE W47.1 STANDARD.
  - ALL THE USED STEELS WILL BE IN COMPLIANCE WITH THE CAN/CSA-G40.21 STANDARD, GRADE 300W FOR SHEETS AND GRADE 350W FOR OPEN PROFILES AND TUBES.
  - BOLTED CONNECTIONS WILL BE IN STAINLESS STEEL.
  - ALL STRUCTURES EXPOSED TO WEATHER WILL BE HOT DIPPED GALVANIZED WITH A ZINC COAT OF 600 G/M<sup>2</sup> IN COMPLIANCE WITH CAN/CSA-G164 STANDARD.

INSTALLATION TYPE 4



INSTALLATION TYPE 6



-	-	-
-	-	-
15 03 27	ISSUE FOR TENDER	M.W.
Y   M   D	MODIFICATION	BY
-- --	ISSUE DATE	--

CLIENT:  
**CIMAISE - CANADIAN SPACE AGENCY**

PROJECT:  
**#2015-014 - ROOF REFLECTION C-D-E-F**




TITLE:  
**INSTALLATION DETAILS**

150 CHAMIN DES GRANITES  
140 BEAUFORT, G8B 0G1  
TEL: 418-849-9987, SANS FRAIS: 1-888-949-9987  
FAX: 418-849-4143, SANS FRAIS: 1-888-949-4143  
CELL: 418-272-8997  
COURRIEL: ZMASSE@SLIM.ORG




**SLIM CONSTRUCTION**

- REF. CLIENT:	-	- DATE:	2015-04-01
- PROJECT:	#2015-014	- PAGE:	
- SCALE:	IND.		
- SIZE:	ARCH D (24" X 36")		2 OF 3

INSTALLATION TYPE 5



STANDARD INSTALLATION OF HORIZONTAL CABLE




DETAIL 05 - ASSEMBLY - HORIZONTAL CABLE W/ ENERGY ABSORBER  
SCALE 1:10

GENERAL NOTES:

1. ALL MEASUREMENTS MUST BE VALIDATED ON SITE BY THE CONTRACTOR.
2. ALL WELDS MUST BE MADE BY A COMPANY CERTIFIED BY THE CANADIAN WELDING BUREAU IN COMPLIANCE WITH THE STANDARD W59. THE WELDERS AND THE FIRM WILL ALSO BE IN COMPLIANCE TO THE W47.1 STANDARD.
3. ALL THE USED STEELS WILL BE IN COMPLIANCE WITH THE CAN/CSA-G40.21 STANDARD, GRADE 300W FOR SHEETS AND GRADE 350W FOR OPEN PROFILES AND TUBES.
4. BOLTED CONNECTIONS WILL BE IN STAINLESS STEEL.
5. ALL STRUCTURES EXPOSED TO WEATHER WILL BE HOT DIPPED GALVANIZED WITH A ZINC COAT OF 600 G/M<sup>2</sup> IN COMPLIANCE WITH CAN/CSA-G164 STANDARD.

THALER 702 SYSTEM - WALL MOUNT INSTALLATION



K-702 THALER SYSTEM - WALL MOUNTING  
SCALE 1:10

-	-	-
-	-	-
-	-	-
15 03 27	ISSUE FOR TENDER	M.W.
Y   M   D	MODIFICATION	BY
-- --	ISSUE DATE	--

CLIENT:  
**CIMAISE - AGENCE SPATIALE**

PROJECT:  
**#2015-014 - ROOF REFLECTION C-D-E-F**

TITLE:  
**INSTALLATION DETAILS (2)**



REF. CLIENT:	-	DATE:	2015-04-01
PROJECT:	#2015-014	PAGE:	
SCALE:	IND.		
SIZE:	ARCH D (24" X 36")		