

Publics Works and  
Government Services  
Canada

Travaux publics et  
Services gouvernementaux  
Canada

Canada

100-1960 Robertson Road, Suite 100  
Ottawa (Ontario) K2H 5B9  
(613) 596-6454  
(613) 596-3346\_Fax  
www.bpa.ca

1960, chemin Robertson, bureau 100  
Ottawa (Ontario) K2H 5B9  
(613) 596-6454  
(613) 596-3346 – télécopieur  
www.bpa.ca

mechanical | electrical | energy | telecommunications  
mécanique | électricité | efficacité énergétique | télécommunications

KEY PLAN  
PLAN-REPÈRE

N.T.S.  
PAS À L'ÉCHELLE

PROJECT NORTH  
NORD DU PROJET

N

4	ISSUED FOR TENDER	2015-04-15
3	ISSUED FOR 100% REVIEW - TENDER	2015-01-30
2	ISSUED FOR 99% REVIEW	2014-10-23
1	ISSUED FOR 66% REVIEW	2014-09-09
revisions	description	date
<div><div>A</div><div>C</div></div>	A detail no. no du détail B location drawing no. no du dessin de localisation C drawing no. no du dessin	<div><div>A</div><div>B</div><div>C</div></div>
project	project  CHILLER REPLACEMENT FOR TRANSPORT CANADA TRAINING CENTRE (BUILDING O-276)	
drawing	dessin  HYDRAULIC BUILDING  CHILLED WATER  DEMOLITION	
Designed By	CARL MUIR	Conçu par
Date	2014-08-21	(yyyy/mm/dd)
Drawn By	CARL MUIR	Dessiné par
Date	2014-08-21	(yyyy/mm/dd)
Reviewed By	DAVID LANDSBERG	Examiné par
Date	2014-09-10	(yyyy/mm/dd)
Approved By	DAVID LANDSBERG	Approuvé par
Date	2014-09-10	(yyyy/mm/dd)
Tender	2015-01-30	Soumission
Project Manager	K. DUNN	Administrateur de projet
Project no.	no du projet  R.060139.002	
Drawing no.	no du dessin  M301	

GENERAL NOTES:

1. LOUD MACHINERY IN OPERATION AT ALL TIMES WITHIN HYDRAULIC BUILDING. USE CAUTION AND PROTECT EQUIPMENT AT ALL TIMES.

DRAWING NOTES:

① EXISTING 800 CGLY-S AND 800 CGLY-R UNDERGROUND TO MAIN BUILDING TO REMAIN.

② LOCATION OF VERTICAL 800 CGLY-S/R DROPS TO UNDERGROUND CONNECTIONS TO MAIN BUILDING. INTERCONNECTION OF TEMPORARY CHILLER TO BE LOCATED HERE AS INDICATED ON OTHER DRAWINGS.

③ EXISTING MATERIAL LOCATED BETWEEN ROOF JOISTS.