



- 7 DISCONNECT AND RELOCATE EXISTING AIR COMPRESSOR. REMOVE BREAKER FROM PANEL E. PROVIDE WIRE AND CONDUIT TO CONNECT THE RELOCATED AIR COMPRESSOR FROM A NEW 15A-3P DISCONNECT FED FROM EXISTING SPLITTER A-1 ONCE THE TEMPORARY CHILLER IS REMOVED.
- 8 PROVIDE COMBINATION STARTERS, WIRING AND CONDUIT FOR FANCOIL UNITS FC-01 AND FC-02. CONNECT FAN COIL UNITS AS INDICATED. REFER TO THE SINGLE LINE DIAGRAM FOR CONNECTION DETAILS.
- 9 PROVIDE 4"x4" PULL BOX AND 1/2" EMT CONDUIT FROM PANEL E FOR PROVISIONS OF CT METERING OF FLUID COOLERS FC-01 AND FC-02. CURRENT TRANSFORMERS ARE SUPPLIED BY DIV. 25 AND INSTALLED BY DIV. 26.
- 10 DISCONNECT AND REMOVE EXISTING 9KVA TRANSFORMER. REMOVE CONDUIT AND WIRING BACK TO SOURCE. REPLACE TRANSFORMER WITH 15KVA 600-120/208V TRANSFORMER AND CONNECTED TO PANEL L.
- 11 TEMPORARILY DISCONNECT UNIT HEATERS AND ASSOCIATED BREAKER FROM PANEL E. REINSTALL THE EXISTING UNIT HEATER. PROVIDE WIRING AND CONDUIT TO SUIT. THE EXISTING UNIT HEATERS ARE TO BE CONNECTED TO A NEW 15A-3P DISCONNECT FED FROM EXISTING SPLITTER A-1 ONCE THE TEMPORARY CHILLER IS REMOVED.

STAGE 5

1. HYDRAULIC BUILDING SHUTDOWN #3 - ISOLATE PANEL E. DISCONNECT TEMPORARY CHILLER. CONNECT NEW CHILLER.
2. START-UP AND COMMISSIONING OF NEW CHILLER.
3. REMOVAL OF TEMPORARY CHILLER AND CONNECTIONS.
4. FINAL COMMISSIONING.
5. COMPLETE SITE RESTORATION, CLEANUP, AND DEMOBILIZATION.