

1 M305 MAIN BUILDING – LOW LEVEL HEATING AND COOLING NEW WORK
SCALE 1:100



2 M305 MAIN BUILDING – GROUND FLOOR HEATING AND COOLING NEW WORK
SCALE 1:100

DRAWING NOTES:

1. SUPPLY AND INSTALL NEW HUMIDIFIERS. COORDINATE WITH DIVISION 26. THE EXISTING MAKE-UP WATER, CONDENSATE DRAINAGE PIPING AND STEAM PIPING CONNECTIONS ARE TO BE RE-USED FOR THE NEW HUMIDIFIERS. CONTRACTOR TO PROVIDE NEW SHUT-OFF VALVE AT MAKE-UP WATER.
2. DIFFERENTIAL PRESSURE SENSOR PROVIDED BY DIV. 25 INSTALLED BY DIV. 23. MOUNT ON WALL AND RUN COPPER SENSING LINES.

c

0 10 20mm 40 60 80 100 120 140 160 180 200mm

Publics Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada

Canada

100-1960 Robertson Road, Suite 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346_Fax
www.bpa.ca

1960, chemin Robertson, bureau 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346 – télécopieur
www.bpa.ca

_bpa

mechanical | electrical | energy | telecommunications
mécanique | électricité | efficacité énergétique | télécommunications



KEY PLAN N.T.S.
PLAN-REPÈRE PAS À L'ÉCHELLE

PROJECT NORTH NORD DU PROJET

LICENSED PROFESSIONAL ENGINEER
D.A. LANDSBERG
2015-05-14
PROVINCE OF ONTARIO

revisions	description	date
2	ISSUED FOR TENDER	2015-04-15
1	ISSUED FOR 100% REVIEW - TENDER	2015-01-30

A detail no. no du détail
B location drawing no. no du dessin de localisation
C drawing no. no du dessin

project projet

CHILLER REPLACEMENT
FOR TRANSPORT CANADA
TRAINING CENTRE
(BUILDING O-276)

drawing dessin

MAIN BUILDING
LOW LEVEL & GROUND FLOOR
HEATING AND COOLING

NEW WORK

Designed By	CARL MUIR	Conçu par
Date	2014-08-21	(yyyy/mm/dd)
Drawn By	CARL MUIR	Dessiné par
Date	2014-08-21	(yyyy/mm/dd)
Reviewed By	DAVID LANDSBERG	Examiné par
Date	2014-09-10	(yyyy/mm/dd)
Approved By	DAVID LANDSBERG	Approuvé par
Date	2014-09-10	(yyyy/mm/dd)
Tender	2015-01-30	Soumission
Project Manager	K. DUNN	Administrateur de projet

Project no. no du projet
R.060139.002

Drawing no. no du dessin
M305