


- GENERAL NOTES:**

 - LOUD MACHINERY IN OPERATION AT ALL TIMES WITHIN HYDRAULIC BUILDING. USE CAUTION AND PROTECT EQUIPMENT AT ALL TIMES.
- DRAWING NOTES:**

◇ CONTROL VALVES, THERMAL WELLS, FLOW METER AND DIFFERENTIAL PRESSURE TRANSMITTER TO BE SUPPLIED BY DIV. 25 AND INSTALLED BY DIV. 23. PROVIDE NIPPLES WHERE REQUIRED.

1
M310

STAGE 3 NEW WORK
N.T.S.



Publics Works and
Government Services
Canada

Travaux publics et
Services gouvernementaux
Canada

100-1960 Robertson Road, Suite 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346_Fax
www.bpa.ca

1960, chemin Robertson, bureau 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346 – télécopieur
www.bpa.ca

mechanical | electrical | energy | telecommunications
mécanique | électricité | efficacité énergétique | télécommunications

KEY PLAN
PLAN-REPÈRE

N.T.S.
PAS À L'ÉCHELLE

PROJECT NORTH

NORD DU PROJET

| 4 | ISSUED FOR TENDER | 2015-04-15 |
|-----------|--|------------|
| 3 | ISSUED FOR 100% REVIEW - TENDER | 2015-01-30 |
| 2 | ISSUED FOR 99% REVIEW | 2014-10-23 |
| 1 | ISSUED FOR 66% REVIEW | 2014-09-09 |
| revisions | description | date |
| A | A detail no. no du détail | |
| B | B location drawing no. no du dessin de localisation | |
| C | C drawing no. no du dessin | |

project

CHILLER REPLACEMENT
FOR TRANSPORT CANADA
TRAINING CENTRE
(BUILDING O-276)

project

drawing

STAGE 3
NEW WORK

dessin

Designed By CARL MUIR
Date 2014-08-21

Conçu par
(yyyy/mm/dd)

Drawn By CARL MUIR
Date 2014-08-21

Dessiné par
(yyyy/mm/dd)

Reviewed By DAVID LANDSBERG
Date 2014-09-10

Examiné par
(yyyy/mm/dd)

Approved By DAVID LANDSBERG
Date 2014-09-10

Approuvé par
(yyyy/mm/dd)

Tender 2015-01-30

Soumission

K. DUNN
Project Manager

Administrateur de projet

Project no.

no du projet

R.060139.002

Drawing no.

no du dessin

M310