

GENERAL NOTES:

1. ALL NEW EQUIPMENT AND PIPING TO BE SEISMICALLY BRACED AS PER NBC.

DRAWING NOTES:


- 1 DISMANTLE THE EXISTING ROOFTOP UNIT C/W ROOFCURB AND ACCESSORIES.
- 2 SUPPLY AND INSTALL NEW ROOFTOP UNITS C/W ROOFCURB AND ACCESSORIES. COORDINATE ALL INSTALLATION AND MEMBRANE WORK WITH OTHER DIVISIONS.
- 3 DISMANTLE ALL INSULATION AND FINISHING FROM EXISTING EXTERIOR DUCTWORK.
- 4 SUPPLY AND INSTALL NEW INSULATION AND FINISHING TO EXISTING EXTERIOR DUCTWORK.

Canada

100-1960 Robertson Road, Suite 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346_Fax
www.bpa.ca


1960, chemin Robertson, bureau 100
Ottawa (Ontario) K2H 5B9
(613) 596-6454
(613) 596-3346 – télécopieur
www.bpa.ca

mechanical | electrical | energy | telecommunications
mécanique | électricité | efficacité énergétique | télécommunications



KEY PLAN N.T.S.
PLAN-REPÈRE PAS À L'ÉCHELLE

PROJECT NORTH NORD DU PROJET



4	ISSUED FOR TENDER	2015-04-15
3	ISSUED FOR 100% REVIEW - TENDER	2015-01-30
2	ISSUED FOR 99% REVIEW	2014-10-23
1	ISSUED FOR 66% REVIEW	2014-09-09

revisions	description	date
A	detail no. no du détail	A
B	location drawing no. no du dessin de localisation	B
C	drawing no. no du dessin	C

project projet

CHILLER REPLACEMENT
FOR TRANSPORT CANADA
TRAINING CENTRE
(BUILDING O-276)

drawing dessin

MAIN BUILDING
ROOF
VENTILATION

DEMOLITION AND NEW WORK

Designed By	CARL MUIR	Conçu par
Date	2014-08-21	(yyyy/mm/dd)
Drawn By	CARL MUIR	Dessiné par
Date	2014-08-21	(yyyy/mm/dd)
Reviewed By	DAVID LANDSBERG	Examiné par
Date	2014-09-10	(yyyy/mm/dd)
Approved By	DAVID LANDSBERG	Approuvé par
Date	2014-09-10	(yyyy/mm/dd)
Tender	2015-01-30	Soumission
Project Manager	K. DUNN	Administrateur de projet
Project no.		no du projet

R.060139.002

Drawing no. no du dessin

M503