



ADDENDUM N° 2

Date: June 8, 2015

Project: London Fire Panel Upgrade, Phase 2

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided in amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

1. Refer to Fire Alarm Schedules on drawing E002. Regarding the monitoring of the generators the following statement should be included:

ADD:

"Provide addressable modules and connect to generator control panel as required for monitoring of generators in buildings #14 and #16."

2. Refer to drawing E104. Regarding the installation methods within the Farmhouse Building #11, the following statement should be included:

ADD:

"Provide surface mounted Wiremold raceway and boxes for routing of fire alarm wiring and mounting of fire alarm devices within Farmhouse – Building #11."

All other conditions and requirements remain unchanged.