



**RETURN BIDS TO/ RETOURNER LES
SOUMISSIONS À:**

Foreign Affairs, Trade and Development
Canada
Embassy of Canada
501 Pennsylvania Ave NW
Washington, D.C., 20001

Attention: Pema Tulotsang

SOLICITATION AMENDMENT

The referenced document is hereby revised;
unless otherwise indicated, all other terms and
conditions of the Solicitation remain the same.

MODIFICATION DE L'INVITATION

Ce document est par la présente révisé; sauf
indication contraire, les modalités de l'invitation
demeurent les mêmes

TITLE - SUJET Integrated Security System Maintenance at the Embassy of Canada, Washington, D.C.	
SOLICITATION NO. – NO. DE L'INVITATION # 15-99856	
AMENDMENT NO.–NO DE MODIF. 002	DATE JUNE 8, 2015
SOLICITATION CLOSES / L'INVITATION PREND FIN On June 15, 2015 at 14:00 hours Eastern Daylight Time (EDT). Le 15 juin 2015 à 14:00h heure avancée de l'Est (HAE).	
ADDRESS ENQUIRIES TO – ADRESSER TOUTES QUESTIONS À: RHONDA TOUESNARD	
TELEPHONE:	EMAIL - COURRIEL: RHONDA.TOUESNARD@INTERNATIONAL.GC.CA
DESTINATION OF GOODS/SERVICES-DESTINATION DES BIENS/SERVICES Embassy of Canada 501 Pennsylvania Ave NW Washington, D.C., 20001	
VENDOR/FIRM NAME AND ADDRESS – RAISON SOCIALE ET ADRESSE DU FOURNISSEUR/DE L'ENTREPRENEUR Telephone No. - No de telephone.: Facsimile No. – No de telecopieur:	
NAME AND TITLE OF PERSON AUTHORIZED TO SIGN ON BEHALF OF THE VENDOR/FIRM NOM ET TITRE DE LA PERSONNE AUTORISÉE À SIGNER AU NOM DU FOURNISSEUR/DE L'ENTREPRENEUR	Corporate Seal
_____ Signature	
_____ Date	

Request for Proposal (RFP)
Foreign Affairs, Trade and Development Canada (DFATD)

SOLICITATION AMENDMENT

This solicitation amendment is raised to:

1. Provide answers to bidder's questions in relation to the RFP as detailed in Section 1 below.
2. Amend the Request for Proposal as detailed in Section 2 below.

Section 1

Q2: What version of the Summit platform are they running?
How many readers on the system?
What type of readers?
How many controllers and locations?
Is there any camera integration?
How many work stations?
Is there integration between other software's such as Oracle, People soft etc.?

A2: Refer to Section 2 below.

Section 2

2.1 At Annex "A" Statement of Work:

DELETE section 4.0 Scope of Work in its entirety.

REPLACE BY:

4.0 Scope of Work

The System is comprised of GE Security's Summit series access control system (version 4.00), complete with integrated Photo Badging, Elevator Control, CCTV, and Warm-Stand-By options; Panasonic's HD 300A series Digital Video Recorders; an integrated Pelco 9500 series Matrix; Aiphone's LEF series Intercom system and Autonomous Control Units.

There are 86 Proximity readers on the system, 12 controllers and 5 workstations.

There is no integration between any other software.

The Embassy is operational twenty-four hours per day and therefore requires a Contractor who is capable of responding very quickly and competently should there be an emergency with the security System at any time of the day.

Note: the term "emergency" comprises a total or partial breakdown or disruption in security camera or security software service which impairs the complete monitoring of the Embassy.