

## WALL ASSEMBLIES

**W1 PARTITION WALL**  
To U/S of Finished Ceiling  
15.9 mm GWB  
92 mm Steel Stud @ 600 o.c.  
89 mm Acoustic Batt  
15.9 mm GWB

**W2 PARTITION WALL: ENHANCED SPEECH PRIVACY**  
To U/S of Structure  
Refer to Detail 7/A14  
T/O Floor Slab to U/S of ACT:  
15.9 mm GWB  
92 mm Steel Stud @ 600 o.c.  
89 mm Acoustic Batt  
15.9 mm GWB

T/O of ACT to U/S of Structure:  
92 mm Steel Stud @ 600 o.c.  
38 mm Double Layer Semi-Rigid Foil  
Backed Insulation

**W3 DEMISING WALL**  
To U/S of Structure  
BCBC Wall Assembly - S4a  
15.9 mm GWB  
92 mm Steel Stud @ 600 o.c.  
89 mm Acoustic Batt  
15.9 mm GWB


**W4 SECURE WALL**  
To U/S of Structure  
15.9 mm GWB  
Metal Security Mesh  
(Confirm Side w/ NTAG)  
92 mm Steel Stud @ 600 o.c.  
89 mm Mineral Fibre  
15.9 mm GWB

**W5 (E) WALL EXTENSION**  
Extend (E) Wall To U/S of Structure  
(E) GWB  
(E) Steel Stud  
(E) Acoustic Batt  
(N) 15.9 mm GWB



From T/O (E) Wall to U/S of Structure:  
15.9 mm GWB  
92 mm Steel Stud @ 600 o.c.  
89 mm Acoustic Batt  
15.9 mm GWB

**W6 FURRING WALL**  
To U/S of Finished Ceiling  
15.9 mm GWB  
92 mm Steel Stud @ 600 o.c.

## DOOR TYPES:



## FRAME TYPES:



## DOOR & WINDOW SCHEDULE

### SECOND & FOURTH FLOOR - 300 MAIN STREET


DOOR/WINDOW											FRAME					REMARKS
NUM.	SIZE (W x H)	FROM	TO	F.R.R.	H.W. CODE	TYPE	MATL	CORE	FINISH	GLAZ.	MATL	TYPE	FINISH	GLAZ.		
SECOND FLOOR																
D203A	914 x 2134	SECURE LOBBY 2-106	INTERVIEW ROOM 2-103	-	10	D	WD	SOLID	(E)*	-	PL	B	A	-	SINGLE GLAZED TEMPERED	RELOCATE (E) DOOR D203A TO (N) LOCATION REUSE (E) HARDWARE. TOUCH-UP FINISH.
D203B	914 x 2134	INTERVIEW ROOM 2-103	OPEN OFFICE AREA 2-108	-	10	D	WD	SOLID	CLEAR	-	HM	E	PT	-		(N) DOOR. REUSE (E) HARDWARE ON (N) DOOR D203B. (N) FINISH TO MATCH (E) WOOD DOORS.
D206A	914 X 2134	CORRIDOR	SECURE LOBBY 2-106	-	10	B	HM	-	PT	-	HM	D	PT	WIRED	(E) DOOR & HARDWARE TO REMAIN	
D207	914 X 2134	CORRIDOR	LOBBY 2-107	-	1	A	HM	-	PT	WIRED	HM	C	PT	-	(E) DOOR TO REMAIN. (N) HARDWARE	
D208	914 x 2134	OPEN OFFICE AREA 2-108	LOBBY 2-107	-	2	D	WD	SOLID	(E)*	-	PL	B	-	-	REUSE (E) DOOR D208. (N) HARDWARE	
D209	914 x 2134	CORRIDOR 2-113	MEETING ROOM 2-109	-	10	D	WD	-	(E)*	-	PL	A	-	-	(E) DOOR & HARDWARE TO REMAIN	
D211	914 x 2134	LOBBY 2-107	TRAINING ROOM 2-111	-	3	C	WD	SOLID	(E)*	-	PL	B	-	-	REUSE (E) DOOR D205. (N) HARDWARE	
D212	1829 x 2134	SERVER CLOSET 2-112	CORRIDOR 2-113	-	4	B	HM	HOLLOW	PT	-	HM	C	PT	-	(N) BI-PART SWING DOORS & (N) HARDWARE	
FOURTH FLOOR																
D400	914 x 2134	ENTRANCE 400	PUBLIC CORRIDOR	-	5	C	WD	-	(E)	WIRED	HM	C	PT	-	(E) DOOR TO REMAIN. (N) HARDWARE	
D401A	914 x 2134	PUBLIC CORRIDOR	BOARDROOM 401	-	6	C	WD	-	(E)	WIRED	HM	C	PT	-	(E) DOOR TO REMAIN. (N) HARDWARE	
D401B	914 x 2134	ENTRANCE 400	BOARDROOM 401	-	10	D	WD	SOLID	(E)*	-	PL	A	-	-	SINGLE GLAZED TEMPERED	REUSE (E) DOOR, SIDELIGHT & HARDWARE D408 (N) FILM
D402	914 x 2134	CORRIDOR 404	QUIET ROOM 402	-	7	D	WD	SOLID	(E)*	-	PL	A	-	-		REUSE (E) DOOR & SIDELIGHT D410. MODIFY (E) HARDWARE. (N) FILM
D403	914 x 2134	CORRIDOR 404	OFFICE 403	-	10	D	WD	SOLID	(E)*	-	PL	A	-	-	SINGLE GLAZED TEMPERED	REUSE (E) DOOR, SIDELIGHT & HARDWARE D406 (N) FILM
D407	914 x 2134	SHARED EQUIPMENT 406	STORAGE 407	-	8	D	WD	SOLID	(E)*	-	PL	B	-	-		REUSE (E) DOOR & SIDELIGHT D413 (N) HARDWARE
D415	914 x 1982	EXIT CORRIDOR	KITCHEN 415	-	9	D	HM	-	PT	-	HM	C	PT	-	(E) DOOR TO REMAIN. (N) HARDWARE	
SECOND FLOOR - WINDOWS																
W207	EXISTING	CORRIDOR 2-113	LOBBY 2-107	-	-	-	-	-	-	-	HM	-	PT	WIRED	(E) TO REMAIN	
W211	EXISTING	CORRIDOR 2-113	TRAINING ROOM 2-111	-	-	-	-	-	-	-	HM	-	PT	WIRED	(E) TO REMAIN	
FOURTH FLOOR - WINDOWS																
W401A	500 x 1803	PUBLIC CORRIDOR	BOARDROOM 401	-	-	-	-	-	-	-	HM	-	PT	WIRED	(E) LITE TO REMAIN. (N) FILM	
W403	920 x 2591	CORRIDOR 404	OFFICE 403	-	-	-	-	-	-	-	PL	-	-	-	SINGLE GLAZED TEMPERED	REUSE (E) WINDOW W405A. (N) FILM
* CLEAN & TOUCH-UP (E) DOOR FINISH AS REQUIRED TO MATCH GOOD NOTE: SEE SPECIFICATIONS FOR NEW HARDWARE																

\* CLEAN & TOUCH-UP (E) DOOR FINISH AS REQUIRED TO MAKE GOOD  
NOTE: SEE SPECIFICATIONS FOR NEW HARDWARE

## FINISH SCHEDULE

NUM	ROOM NAME	FLOOR		CEILING		NORTH WALL		EAST WALL		SOUTH WALL		WEST WALL		REMARKS
		FINISH	BASE	MATERIAL	MATERIAL	FINISH	COLOUR	MATERIAL	FINISH	COLOUR	MATERIAL	FINISH	COLOUR	
2-103	INTERVIEW ROOM	CT-1	RB-1	(E) ACT	(N) GWB	(N) PT	-	(E) GWB / (N) GWB	(E) VWC / (N) PT	-	(E) GWB	(N) PT	-	SEE DETAIL S4a FOR EAST WALL CONNECTION DETAIL OF (N) GWB TO (E) GWB. PATCH & REPAIR (E) VWC ON WEST WALL WHERE (E) WALL REMOVED. (E) BLINDS TO REMAIN
2-106	SECURE LOBBY	(E)	RB-1	(E) ACT	(E) GWB	(E) VWC	-	(E) GWB / (N) GWB	(N) PT	-	(E) GWB	(N) PT	-	PATCH & REPAIR (E) GWB. MAKE GOOD CONNECTION B/W (N) GWB TO (E) GWB
2-107	LOBBY	CT-1	RB-1	(E) ACT	(N) GWB	(N) PT	-	(E) GWB	(N) PT	-	(E) GWB	(N) PT	-	PATCH & REPAIR (E) GWB. MAKE GOOD CONNECTION B/W (N) GWB TO (E) GWB
2-108	OPEN OFFICE AREA	CT-1	RB-1	(E) ACT	(E) GWB	(N) PT	-	(E) GWB / (N) GWB	(E) VWC / (N) PT	-	(E) GWB	(E) VWC	-	PATCH & REPAIR (E) VWC ON WEST WALL WHERE (E) WALL REMOVED
2-109	MEETING ROOM	CT-1	RB-1	(E) ACT	(E) GWB	(N) PT	-	(E) GWB	(E) VWC	-	(E) GWB	(E) VWC	-	REMOVE (E) VWC & (E) GWB OF EAST WALL. REPLACE W/ (N). PAINT FINISH
2-110	OPEN OFFICE AREA	CT-1	RB-1	(E) ACT	(E) GWB	(N) PT	-	(N) GWB	(N) PT	-	(E) GWB	(E) VWC / (N) PT	-	REMOVE (E) VWC ON (E) GWB OF WEST WALL. PATCH & REPAIR FOR (N) PAINT FINISH
2-111	TRAINING ROOM	CT-1	RB-1	(E) ACT	(E) GWB / (N) GWB	(N) PT	-	(N) GWB	(N) PT	-	(E) GWB / (N) GWB	(N) PT	-	REMOVE (E) VWC ON (E) GWB OF WEST WALL. PATCH & REPAIR FOR (N) PAINT FINISH
2-112	SERVER CLOSET	CT-1	RB-1	(E) ACT	(N) GWB	(N) PT	-	(E) GWB	(E) VWC / (N) PT	-	(E) GWB	(E) VWC	-	REMOVE (E) VWC ON SOUTH WALL. PATCH & REPAIR FOR (N) PAINT FINISH
2-113	CORRIDOR	CT-1	RB-1	(E) ACT	(E) GWB	(E) VWC	-	-	-	-	(E) GWB / (N) GWB	(N) PT	-	REMOVE (E) VWC ON SOUTH WALL. PATCH & REPAIR FOR (N) PAINT FINISH
400	ENTRANCE	CT-2	RB-2	(E) ACT	(E) GWB	(N) PT	-	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	PATCH & REPAIR (E) GWB. MAKE GOOD CONNECTION B/W (N) GWB TO (E) GWB
401	BOARDROOM	CT-2	RB-2	(E) ACT	(E) GWB / (N) GWB	(N) PT	-	(E) GWB	(N) PT	-	(N) GWB	(N) PT	-	PATCH & REPAIR (E) GWB. MAKE GOOD CONNECTION B/W (N) GWB TO (E) GWB
402	QUIET ROOM	CT-2	RB-2	(E) ACT	(N) GWB	(N) PT	-	(E) GWB	(N) PT	-	(N) GWB	(N) PT	-	
403	OFFICE	CT-2	RB-2	(E) ACT	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	
404	CORRIDOR	CT-2	RB-2	(E) ACT	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	-	-	-	
405	OPEN OFFICE AREA	CT-2	RB-2	(E) ACT	(N) GWB	(N) PT	-	(E) GWB	(N) PT	-	(E) GWB	(N) PT	-	PATCH & REPAIR (E) GWB FOR (N) PAINT FINISH
406	SHARED EQUIPMENT	CT-2	RB-2	(E) ACT	(E) GWB / (N) GWB	(N) PT	-	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	
407	STORAGE	CT-2	RB-2	(E) ACT	(E) GWB	(N) PT	-	(N) GWB	(N) PT	-	(N) GWB	(N) PT	-	
415	KITCHEN	(N) SV	RB-2	(E) ACT	(E) GWB / (N) GWB	(N) PT	-	(E) GWB / (N) GWB	(N) PT	-	(N) GWB	(N) PT	-	PATCH & REPAIR (E) GWB FOR (N) PAINT FINISH

NOTE: SEE INTERIOR ELEVATIONS FOR BASE, TRIM & ADDITIONAL INFORMATION



USE ISSUED FOR TENDER REVISION FOR PERMITS		
5	ISSUED FOR TENDER	2015-05-14
4	99% CONSOLIDATED SUBMISSION	2015-04-21
3	CLASS A COSTING	2015-04-07
2	99% SUBMISSION	2015-04-06
1	50% SUBMISSION	2015-03-20
Revision/	Description/Description	Date/Date
Client/client		

**CAN NOR and PUBLIC WORKS & GOVERNMENT SERVICES**  
800 BARRARD ST.  
VANCOUVER, BC

Project title/Titre du projet  
**4th Floor - 300 Main Street  
Whitehorse, YT**

**CAN NOR Relocation  
Consolidated**

Consultant Signature Only

Designed by/Concept par  
**LM**

Drawn by/Dessiné par  
**LM, CM**

PWGSC Project Manager/Administrateur de Projets YPSGC  
**CYNDI OSTER**

PWGSC, Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'ingénierie, YPSGC  
**PREETIPAL PAUL**

Client/client  
**CAN NOR**

Drawing title/Titre du dessin  
**ASSEMBLIES & SCHEDULES**