

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

## **Addendum #1**

### **Drawings:**

1. Add:

Add the following drawings to the construction documents issued for information only. Contractors are advised to visit the site to make their own assessment of the existing conditions as they may vary from the drawings:

EX-1 of 5 – Original Drawing  
EX-2 of 5 – Original Drawing  
EX-3 of 5 – Original Drawing  
EX-4 of 5 – Original Drawing  
EX-5 of 5 – Original Drawing

2. Add:

Add the following drawings to the construction documents:

C10 – Electrical  
ESK-E1 – Site Plan – Electrical Layout and Trench Details

Contractors are advised that all work associated with this job shall be included in the bid price for this work. Contractor shall include all plant, equipment, materials and labour including, but not limited to, treated timber poles, PVC conduits complete with pull ropes, end cap termination up through deck, and termination of conduits through end of deck.

### **Specifications:**

1. Refer to Section 35 59 13.19 – Rubber Marine Fenders - Section 2.1.1.1.6:

Delete

“The face of the fender shall be no more than 550mm wide and no less than 500mm wide.”

Replace with

“The face of the fender shall be no less than 500mm wide”.

2. Refer to Section 35 59 13.19 – Rubber Marine Fenders - Section 2.1.2.1.6:

Delete

“The face of the fender shall be no more than 350mm wide and no less than 300mm wide.”

Replace with

“The face of the fender shall be no less than 300mm wide.”

**Issued for Clarification:**

1. Contractors are advised that all 16mm dia. galvanized spikes required to fasten all 200 x 200mm cross-ties to 200 x 200mm longitudinals shall be revised to 19mm dia. galvanized spikes.
2. Contractors are advised that all cribs shall be married together. Cribs 3 and 4 were detailed on the drawings where they require additional blocking to accept the spliced longitudinals. Cribs 17-20 are required to be spliced to remaining structure as well, but due to the fact these cribs are sloped, exact splice lengths may vary.

By submission of its bid, the bidder confirms that it has read and understands the requirements expressed in all addenda and has included all cost of these requirements in its total bid amount.

All other terms and conditions remain unchanged.

\*\*\*\*\*