

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> Sanitary Sewer Upgrades - PRC, NB	
<b>Solicitation No. - N° de l'invitation</b> EC373-160208/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> R.058866.001	<b>Date</b> 2015-06-11
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-100-3628	
<b>File No. - N° de dossier</b> PWB-5-38016 (100)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-06-16</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> MacDonald, Anne (PWB) D.	<b>Buyer Id - Id de l'acheteur</b> pwb100
<b>Telephone No. - N° de téléphone</b> (902) 626-4949 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Addendum # 1****June 11, 2015****ED373-160208**

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THIS ADDENDA SHALL FORM PART OF THE CONTRACT DOCUMENTS.

Q1 : How much asphalt will have to be put down?

A1 : 3,800 m<sup>2</sup>.

Q2: What are the locked boxed along the fence line?

A2: Refer to the communications drawing.

Q3: In regards to the fence, do we have to reinstate what we take out?

A3: Yes.

Q4: In regards to the rock quantity, how did you come up with that number? Were there any test pits or bore holes done?

A4: The rock quantity is an estimate.

Q5 : What is to be done with the excess fill?

A5: The excess fill can be trucked dumped and well graded to eliminate water retention, at a location to be determined by Agriculture and Agri-Food Canada, within the Fredericton Potato Research Grounds.

**Unit Price Table:**

A revised unit price table has been provided with larger spaces for your bid. It is not mandatory that you use the revised Unit Price Table.

List of attendees at site visit attached.

# APPENDIX 1

PW3536 - PRG Sanitary Sewer Upgrade  
Project Number : R.058866.001

Item Number	Spec Section	Description	Units	Quantity	Unit Price	Total				
Column1	Column2	Column3	Column4	Column5	Column6	Column7	Column8	Column9	Column10	Column11
Sanitary Piping										
1	33 31 13	250mm Ø Sanitary Sewer PVC Pipe	m	4						
2	33 31 13	200mm Ø Sanitary Sewer PVC Pipe	m	1050						
3	33 31 13	150mm Ø Sanitary Sewer PVC Pipe	m	55						
4	33 31 13	100mm Ø Sanitary Sewer PVC Pipe	m	5						
5	33 05 14	1200mm Sanitary Manhole	each	14						
Granular Work										
6	33 31 13	Granular Replacement for Unsuitable Material	m³	750						
7	33 31 13	Clean Stone Bedding	m³	50						
8	31 23 10	Rock Excavation	m³	750						
9	32 11 19	150mm Granular Base	m³	637						
10	32 11 23	300mm Granular Subbase	m³	1275						
11	32 12 16	Asphalt Base Type "B"	m²	3830						
12	32 12 16	Asphalt Seal Type "D"	m²	3830						
Miscellaneous										
13	32 16 15	Concrete Sidewalk	m	20						
14	32 92 24	Landscaping - Topsoil and Hydroseed	m²	8580						
15	33 05 14	Existing Manhole Abandonment	Each	8						
16	33 05 14	Removal and Replacement of Handrail	Each	1						
17	33 31 13	Warranty Inspection	Lump Sum	1						

TOTAL PRICE CALCULATED (TPC) Excluding applicable taxes (s) \$

June 9<sup>th</sup> 2015 : 2:00pm Pre-tender Site Visit

Name	Name of Company	Contact #
GEORGE DUBUAY	MONTEN UNDERGROUND SERVICES	G. DUBUAY 453-1778
Kerry Hager	Charter Const	454 5453
Don Phillips	Philson Ltd	455-9810
Ray Russell	"	"
Brad Walter	E. Cummings Contracting	328-2974
Eric Cummings	"	"
Gary Hale	Charmac Const	420-0883
Donald MacDermine	Charmac Construction	449-3151
Paul Cole	Fasoville construction	614 2130