



SAV	42	STEAM VALVE	1	
LSV	24	LIQ. SOLEN. VALVE	1	
RES		RESISTOR	1	
OF	29	OIL FAILURE CONTROL	1	
LP	31	LOW PRESSURE CONTROL	1	
HP	30	HIGH PRESSURE CONTROL	1	
FM		EVAP. FAN MOTOR	1	
CpM	01	COMPRESSOR MOTOR	1	
CH	02	CRANKCASE HEATER		
TH1	28	THERMOSTAT RET. AIR BULB	1	
EF		EVAP. FAN STARTER	1	
TH2	50	THERMOSTAT(DPDT) F. AIR BULB.	1	IN M. PANEL
⊬		NORMALLY CLOSED SWITCH		
⊣⊢		" OPEN "		
CR	.	AUXILARY RELAY	1	
R		RUN HOLDING COIL	1	
1S		START COIL	1	
2S		ID.	1	
TR		TIME RELAY (Pneumatic type)	1	
SS		Switches.	2	
OL		OVELOAD CURRENT PROTECTION	2	
◎	.	INDICATING LIGHTS	2	
AB		AUTO TRANSFORMER STARTER	1	WESTINGH.
ABR	ITEM	DESCRIPTION	QTY.	REMARKS

NOTES: ALL CABLING MUST BE STRANDED CONDUCTORS. BDD TOBE INFORMED OF THE TYPE OF CABLE BEING USED.

WIRING

- - - - - - - -) BY CUSTOMER.
AND ⊢⊣

———————) BY GALT.

■ TERMINAL ON STARTER PANEL

● TERMINAL ON LOCAL CONTROL SWITCH PANEL.

BACK ON PANEL DOOR.



CUT-OUT CONTROL PANEL TYPE 12 1414 PH-K

NOTES:

TH1: BULB TO BE INSTALLED IN RET. AIR

TH2: S/W T'STAT TO BE INSTALLED IN FRESH AIR DUCT.

NO.	DATE	NO.	DESCRIPTION	DATE	IN
2	FEB-28-77 A	4	CHECK CONTROL PANEL	JAN 24-77	SF
2	FEB-24-77 SH	3	REVISION FROM CU NOTATIONS	NOV-30-76	SF
1	FEB 5 77 SH	2	ST. V CIRCUIT + TH2 + EF2	16-10-76	SF
1	JAN-25-77 A				
1	JAN-12-77 AL				
1S	DEC 29 CU 76				
2	NOV 76 SH 76				
4	OCT 20 CU 76				
2	OCT 14 CU 76				
4	-76	1	INITIAL	16-9-76	SF

ISSUES — REVISIONS

GALT EQUIPMENT LTD.
47 MARIE VICTORIN BLVD.
CANDIAC, PQ.

ELECTRICAL WIRING DIAGRAM.
UNIT: 2-3-5

CUSTOMER NORRIS WARMING FOR BURRARD

HEAT 222

SCALE

D'N SF C'D

DATE SEP. 8. 76.

CONTRACT 3290

DWG. 3290-12C1-2