

CONTROL MANIFOLD SUCTION
INSTALL HORIZONTAL ON DECK HEAD
POTATOE ROOM

CONTROL MANIFOLD SUCTION
INSTALL HORIZONTAL ON DECK HEAD
COLD COOL ROOM N°1

CONTROL MANIFOLD SUCTION
INSTALL HORIZONTAL ON DECK HEAD
COLD-COOL ROOM N°2

CONTROL MANIFOLD SUCTION
INSTALL HORIZONTAL ON DECK HEAD
DAIRY ROOM

CONTROL MANIFOLD SUCTION
INSTALL HORIZONTAL ON DECK HEAD
VEGETABLE ROOM



COLD COOL ROOM N°1 & N°2
LIQUID LINE CONTROL PANEL QTY: 2

DAIRY & POTATOE ROOM
LIQUID LINE CONTROL PANEL QTY 2

VEGETABLE ROOM
LIQUID LINE CONTROL PANEL QTY: 1

CARGO ROOM
LIQUID LINE CONTROL PANEL QTY 2

TYP 3/4 x 3/4 x 3/32" TH

TYP 1/2" TH

INLET 1 1/4" x 1 1/4" x 1 1/4"

ITEM	QTY	DESCRIPTION	REMARKS
243	4	BALL VALVES 5/8"ODF	
244	4	HAND EXP VALVES 3/8"ODF	
243	4	HAND VALVE 1/4" x 1/4" FL	
242	4	TX VALVES 3/8" - 5/8"	
241	4	BALL VALVES 1/2" ODF	
240	2	SOLENOID	
239	2	STRAINER	
238	2	INLET HAND VALVE	
237	2	DEFROST TIME CLOCK	
236	2	ROOM THERMOSTAT 10' CAP	
235	2	DIAL THERMOMETER	

ITEM	QTY	DESCRIPTION		REMARKS
73	10	HAND VALVE	1/4	6251
66	2	BALL VALVE	1 1/8 ODF	V34 207
65	2	BALL VALVE	1 1/8 ODF	V34 206
66	7	" "	7/8 ODF	V34 204
68	12	" "	5/8 ODF	V34 202
56	15	BALL VALVE	1/4 ODF	V34 201
80	10	STRAINER W FLANGE	1/4 ODF	T56 A
74	5	DIAL THERMOMETER 10' CAP	2"	BF 80
72	1	EVAP PRESS REG	1 3/8	A7-1
71	1		1 1/8	A7-1
70	2	EVAP PRESS REG	7/8	A7-0
69	1	EVAP PRESS REG	5/8	A7-1
68	1	CHECK VALVE	1 1/8	205
67	1	CHECK VALVE	1 3/8	205
62	6	T'SAT EXP. VALVE	1/8 / 5/8	SFE-1
	-	EXT. EQUAL		
61	4	T'SAT. EXP. VALVE	3/4 / 7/8	SFE-1/2
	-	EXT. EQUAL	POT & DAIRY	
60	5	ROOM THERMOSTAT 10 FT CAP		1609-103
59	2	DEFROST TIME CLOCK		9145-80
	-	TIME INIT. TEMP. TERM		
58	10	HAND EXP VALVES		6251
55	5	LIQUID SOL VALVE		HB6 SL

ISSUED
6 DEC 1976
DEPARTMENT OF TRANSPORT

GALT EQUIPMENT LTD.
47 MARIE VICTORIN BLVD.
CANDIAC, P.Q.

CONTROL PANELS
DOMESTIC & CARGO

CUSTOMER HULL 221
BURRARD DRYDOCK CO. LTD 222

SCALE 1/4" → 1" | CONTRACT C 32 88
D'N PC | C'D CP | DWG 5288.154
DATE 7 DEC 76

NO	DATE	NO	DESCRIPTION	DATE	IN
5	7 DEC 76	6	AS BUILT	APPR PC	

ISSUES REVISIONS