

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Fit-up Construction - Moncton, NB	
Solicitation No. - N° de l'invitation EC015-160250/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.06433.001	Date 2015-06-16
GETS Reference No. - N° de référence de SEAG PW-\$PWB-100-3633	
File No. - N° de dossier PWB-5-38015 (100)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-06-25	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacDonald, Anne (PWB) D.	Buyer Id - Id de l'acheteur pwb100
Telephone No. - N° de téléphone (902) 626-4949 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

ADDENDUM # 2

June 16, 2015

EC015-160250

This Addendum forms part of the Contract Documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Bid Form. Failure to do so may subject Bidder to disqualification.

This addendum consists of:

2 pages

QUESTIONS AND CLARIFICATIONS:

1. Question: Duct insulation requirements are identified in Section 23 07 13 Item 3.5 and on the symbol legend on drawing M2.1 with conflicting information. Which duct insulation specification should be used?

Answer: Duct insulation to be as per the drawing M2.1. Refer to revisions to Section 23 07 13 of this addendum for further clarification.

2. Question: Will the condensate lines from the heat pumps require insulation?

Answer: No, the condensate piping does not require insulation.

SPECIFICATIONS:

1. SECTION 23 07 13 AIR AND WATER SOURCE UNITARY HEAT PUMPS

.1 Part 2 - Products

.1 Delete Item 2.2 Insulation.

.2 Delete Item 2.4 Jackets.

.2 Part 3 - Execution

.1 Delete item 3.5 Ductwork insulation schedule.

2. SECTION 23 81 40 AIR AND WATER SOURCE UNITARY HEAT PUMPS

.1 Part 2 - Products

.1 Delete item 2.2.9.2.

.2 Delete item 2.4.1.

DRAWINGS:

1. DRAWING M2.2 MECHANICAL HVAC DETAILS & SCHEDULES:

.1 Heat Pump Schedule

.1 Under lines HP-A-134 and HP-A-135, replace Remarks items with:
Provide and install condensate drain piping to nearest condensate main
as shown on floor plan.

END OF ADDENDUM