

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Veuillez adresser toute demande de renseignements par écrit à l'attention de l'autorité contractante, Darlene Reay, soit par télécopieur ou par courriel à: darlene.reay@tpsgc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet Steel Sheet Pile Repairs	
Solicitation No. - N° de l'invitation ED001-160238/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.076433.001	Date 2015-06-16
GETS Reference No. - N° de référence de SEAG PW-\$PWC-008-3635	
File No. - N° de dossier PWC-5-38018 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-06-23	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Reay, D (PWC)	Buyer Id - Id de l'acheteur pwc008
Telephone No. - N° de téléphone (902) 566-7518 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Addendum is raised to provide the following answers to questions provided by bidders.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

QUESTION 1

I would like to know to what extent the requirements of the Health and Safety plan are. Does every task need to be identified in safety plan?

ANSWER 1

Every project and site-specific task which results in any task-associated hazard (as per 01 35 29, Par. 1.10 'Hazard Assessment' and Par. 1.11 'Project/Site Conditions') must be addressed as delineated in 01 35 29, Par 1.13 'Health and Safety Plan'.

QUESTION 2

Supplier can't find the bollard that you are requesting. Would you have model number/more specification/dimension regarding the piece.

ANSWER 2

Unit Price Item 3 - Specification Section 05 12 33 (and as noted in various locations on the Drawings) - Mooring Cleats : All indications of '**22kg mooring cleat**' on the drawings and within the specification section noted, are to be replaced with and superseded by '**13 kg mooring cleat (approximately 355mm lg.)**'.