

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Fit-up Construction - Moncton, NB	
Solicitation No. - N° de l'invitation EC015-160250/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.06433.001	Date 2015-06-18
GETS Reference No. - N° de référence de SEAG PW-\$PWB-100-3633	
File No. - N° de dossier PWB-5-38015 (100)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-06-25	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacDonald, Anne (PWB) D.	Buyer Id - Id de l'acheteur pwb100
Telephone No. - N° de téléphone (902) 626-4949 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Addendum # 4**June 18, 2015****EC015-160250**

This Addendum forms part of the Contract Documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Bid Form. Failure to do so may subject Bidder to Disqualification.

This addendum consists of 1 page.

QUESTIONS AND CLARIFICATIONS:

1. Question:
Drawing A-2 note #5 provide wall mounted bracket for owner supplied projector.

Answer:

Disregard the note. Owner will supply and install projector.

2. Question:
Drawing A-5 states most of the furniture is N.I.C. is relocating cabinets A & B by G.C.?

Answer:

Yes, the G.C. is responsible for the relocation of cabinets A & B

3. Question:
No details on window sills and apron. Please provide.

Answer:

Drawing A-2 note #6 should read: "REMOVE EXISTING LAMINATE AT WINDOW SILL AND FINISH EDGE. MAKE GOOD ALL SURFACES TO ACCEPT NEW LAMINATE. PROVIDE AND INSTALL NEW PLASTIC LAMINATE AT EXISTING WINDOW SILL AND FINISH EDGE TO MATCH EXISTING PROFILE. There is no apron, only a 1.5" finish edge.

4. Question:
Will drywall hoarding be required to enclose the old kitchen from the lobby and the new construction from the existing? (demising wall separating room 102 & 103 from beyond)

Solicitation No. - N° de l'invitation

EC015-160250/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

pwb100

Client Ref. No. - N° de réf. du client

R.06433.001

File No. - N° du dossier

PWB-5-38015

CCC No./N° CCC - FMS No/ N° VME

Answer:

Yes, drywall hoarding to be required to enclose the old kitchen from the lobby and the new construction from the existing.