



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

AMENDMENT / MODIFICATION

001

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Highway 93N Paving & Crushing Jasper National Park		
Solicitation No. - No. de l'invitation 5P420-15-5099/A		Date: June 19, 2015
GETS Reference No. - No de reference de SEAG PW-15-00686940		Amendment No. - N° de la modif. 001
Solicitation Closes:		
at - á 02:00 PM	on - le June 23, 2015	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 1

This amendment is issued to answer questions from potential bidders.

- Q1.** Is the Mile 8 pit open/unlocked for Contractors to have access to the pit?
A1. Mile 8 pit is currently locked but will be opened for the successful for the duration of the Contract.
- Q2.** Are there more details or drawings for the bridge noted in the tender?
A2. Refer to Section 33 18 01, "1.4 Design Requirements" for the bridge's design parameters as it is considered complete.
- Q3.** If design of the bridge is included in the tender the tender period should be extended.
A3. No extension to the tender period will be granted.
- Q4.** Is it necessary to erect the bridge in Niblock Pit or is it enough to deliver the components, setting the girders on blocks and securing them?
A4. Section 33 18 01, Clause 1.7.2 is correct. Full assembly of the bridge structural steel on lock blocks is required. Precast deck panels shall not be installed on the steel but stored off the ground adjacent to the bridge steel.
- Q5.** If the bridge is to be erected, is it necessary to grout or bolt any of the pieces together?
A5. Yes it is.
- Q6.** Section 1.7.7.5 says to protect unpainted weathering steel before erection with a waterproofing covering. What is mean by this?
A6. Enclosing the bridge girders in waterproof tarps that cover both the top and bottom flanges will be sufficient.
- Q7.** The contract requires the bridge to be set up on lock blocks in the pit, is that required or can it just be stored there?
A7. Section 33 18 01, Clause 1.7.2 is correct. Full assembly of the bridge structural steel on lock blocks is required. Precast deck panels shall not be installed on the steel but stored off the ground adjacent to the bridge steel.
- Q8.** If set up is required, will you ensure substructure (lock blocks) are placed level and sound in order for the bridge to be erected onto?
A8. Yes.
- Q9.** We are looking at a delivery date of late Sept. / early October, can you please ask if the project completion can be bumped out by at least two weeks?
A9. Contract Completion Date remains unchanged.

All other terms and conditions remain unchanged.