



Fisheries and Oceans  
Canada

Pêches et Océans  
Canada

Materiel and Procurement Services  
200 Kent Street, Station 9W071  
Ottawa, Ontario  
K1A 0E6

**FP802-150044**

**June 18, 2015**

**Subject: Invitation to Tender: FP802-150044**

**Title: Comox Float Reconstruction**

**ADDENDUM: NO. 5**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#5) is hereby issued.

---

- Q1.** Do the interior flanges need to be changed under the mooring well replacement went un-answered. Under 3.9.2 it only states well blocking, joists, cross ties, stringers and liners
- A1.** No, interior flanges shall not to be replaced.

Thank you,

**Jianna-Lee Zomer**  
Senior Contracting Officer,  
Materiel and Procurement Services  
Fisheries and Oceans Canada,  
200 Kent Street, Station 9W071  
Ottawa, ON K1A 0E6  
Tel: (613) 993-4484  
Email: [jianna-lee.zomer@dfo-mpo.gc.ca](mailto:jianna-lee.zomer@dfo-mpo.gc.ca)