


## NTS

1. NEW DATA AND TELEPHONE CABLEING TO BE EXTENDED BY OTHERS THROUGH ACCESSIBLE FLOOR PLENUM FROM FILE ROOM FLOOR TILE BOXES TO ADJACENT COMMUNICATIONS ROOM RACKS.
2. DISCONNECT AND REMOVE ACCESS CONTROL DEVICES AS INDICATED INCLUDING ALL ASSOCIATED CONDUIT AND WIRING BACK TO SOURCE, TURN OVER REMOVED ACCESS CONTROL DEVICES TO DEPARTMENTAL REPRESENTATIVE.
3. DISCONNECT LIGHT SWITCHES AND REMOVE ALL ASSOCIATED CONDUIT AND WIRING BACK TO SOURCE, TURN OVER SWITCHES TO DEPARTMENTAL REPRESENTATIVE.
4. OCCUPANCY SENSORS IN ESDC FILE ROOM TO BE SET FOR 20 MINUTE DELAY.
5. RELOCATED FROM SECOND FLOOR ZONE B.
6. WALL MOUNTED RACK FOR TWO ZONE CENTRALIZED SOUND MASKING SYSTEM, CONNECT SOUND MASKING SYSTEM WITH 2#12, #14 BOND IN 21MM C FROM EXISTING CIRCUIT TP4-1#16.
7. DAISY-CHAIN PINK NOISE SOUND MASKING SPEAKERS BACK TO SOUND MASKING HEAD END SYSTEM WITH 2C#18 SPEAKER WIRE IN 16MM C (TYPICAL).
8. SUPPLY AND INSTALL ONE NEW LUMINAIRE REMOVED OCCUPANCY SENSOR, INSTALL SENSOR ON THE EXISTING LUMINAIRE AND CONNECT TO MODIFIED LIGHTING SYSTEM, OCCUPANCY SENSOR TO BE LUTRON #MOS-CMZW-15-WH OR EQUAL TO MATCH EXISTING.



project	proiet
---------	--------

ESDC CONSOLIDATION  
FIT-UP  
JEAN CANFIELD  
BUILDING  
CHARLOTTETOWN, PEI

drawing dessin

# MAIN FLOOR PLAN ZONE A ELECTRICAL POWER, COMMUNICATIONS & LIGHTING

designed FSC BENC / ADI BENC 60064

2015-03-04

date	2015-05-04
drawn	MEM CFT
	dessiné

date 2015-03-04

approved	approuvé
----------	----------

date \_\_\_\_\_

Tender	Soumission
--------	------------

PWGSC Project Manager / Administrateur de projets TPSGC

project number	no. du projet
----------------	---------------

R.061033.001

drawing no.	no. du dessin
-------------	---------------


F1 OF 4

LI 01 4


E-DRM/GDD-E: 516339



SCALE : 1:100



0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m




SCALE : 1:100



SCALE : 1:100



0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10



SCALE : 1:100