

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

| | |
|---|--|
| Title - Sujet CanNor Relocation & Renovation | |
| Solicitation No. - N° de l'invitation EZ899-160207/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client | Date 2015-06-26 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7526 | |
| File No. - N° de dossier PWY-5-38033 (019) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-02 | Time Zone Fuseau horaire Pacific Daylight Saving Time PDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY) | Buyer Id - Id de l'acheteur pwy019 |
| Telephone No. - N° de téléphone (604) 658-2755 () | FAX No. - N° de FAX (604) 775-6633 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CanNor - Elijah Smith Building - Whitehorse, YT | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation

EZ899-160207/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-5-38033

Buyer ID - Id de l'acheteur

pw019

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Please find Addendum #2 attached.

All other terms and conditions remain unchanged.

GENERAL

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

ARCHITECTURAL SPECIFICATIONS

ADD 01 11 55 General Instruction

1.11 CONTRACTOR USE OF PREMISES

- .16 Contractor responsible for installing and removing protection measures during delivery and movement of materials and equipment. Contractor will be responsible for repairing any damage to finishes in the public corridors caused by construction activities, this includes replacement if found necessary by the Departmental Representative.

ADD 01 52 00 Construction Facilities

1.7 SITE STORAGE AND LOADING

- .4 Area for a dump trailer will be provided at the existing loading dock, coordinate location with Departmental Representative.
- .1 Dump trailer must be removed at the end of each shift.
- .2 Location of dump trailer must not interfere with regular delivery activities.

REPLACE 08 71 00 Door Hardware

3.5 SCHEDULE

- .4 Door Hardware Group No. 4: D212

| Qty | Description | Catalogue Number | Finish | Mfr |
|-----|-------------------|------------------|--------|-----|
| 6 | Hinge | 5BB1 114 x 102 | 652 | IVE |
| 2 | Manual Flush Bolt | FB458 | 626 | IVE |
| 1 | Classroom Lock | L9070L 03B | 626 | SCH |
| 1 | Cylinder | ML2057 | 626 | MED |
| 2 | OH | 100H | 630 | GLY |
| 2 | Closer | 1461 REG | 689 | LCN |

REPLACE 09 65 16 Resilient Sheet Flooring

2.1 MATERIALS – SHEET FLOORING

Replace Vinyl Sheet with the following:

- .1 Linoleum sheet flooring: ASTM F2034, Type 1, homogenous, composed of natural ingredients which are mixed and calendered onto a jute backing:
 - .1 Pattern: marbleized.
 - .2 Total Thickness: 2.5 mm.
 - .3 Sheet Width: 2000 mm.
 - .4 Wear Layer: UV cured, double layer.
 - .5 Maintenance: No wax, no polish, no finish for the life of the product.
 - .6 Colour: to be selected from manufacturers standard colour range.

ARCHITECTURAL DRAWINGS

A01 Second Floor Demolition Plan

- REVISE** Construction hoarding of 2x4 framing with 16mm plywood both sides, or equivalent. GWB will be accepted in place of plywood, if more cost effective.

END OF ADDENDUM