

FLOOR PLAN – ELECTRICAL POWER AND COMMUNICATIONS

SCALE: 1:50

0m 1m 2m 3m 4m 5m

NOTES:

1. DATA OUTLETS DENOTED 'FN' ARE TO BE FED FROM COMMUNICATIONS RACK IN ROOM 109A. ALL OTHER VOICE AND DATA OUTLETS ARE TO BE FED FROM COMMUNICATIONS RACK IN ROOM 122.
2. EXISTING SEWERAGE PUMP CONTROLLER TO REMAIN OPERATIONAL AT ALL TIMES DURING CONSTRUCTION. PROVIDE TEMPORARY POWER AS REQUIRED.
3. PROVIDE POWER TO TRAP PRIMER VIA RECEPTACLE OR DIRECT CONNECTION AS REQUIRED.
4. RECEPTACLES TO BE RACK MOUNTED.
5. WORKSTATION RECEPTACLES TO BE FED THROUGH NEAREST WALL, THEN THROUGH THE FURNITURE SYSTEMS. PROVIDE FURNITURE FEED WHIPS AND RECEPTACLES/OUTLETS. RUN ALL WIRING AND PERFORM ALL TERMINATIONS.
6. EXTERIOR RECEPTACLES TO BE COMPLETE WITH WEATHERPROOF-WHILE-IN-USE ENCLOSURES, IN ACCORDANCE WITH CEC 2015 SECTIO N26-702.

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

FOWLER BAULD & MITCHELL
architecture
Fowler Bauld & Mitchell Ltd.
PO Box 514, Suite 102
1660 Hollis Street
Halifax, Nova Scotia B3J 2R7
Tel: 902 429 4100
Fax: 902 423 3063
architects@fbm.ns.ca
www.fbm.ns.ca

CBCL LIMITED
Consulting Engineers
ISO 9001 CERTIFIED

revisions		date
1	ISSUED FOR TENDER	JUN. 4 2015

project / projet: ARGO BUILDING BEDFORD INSTITUTE OF OCEANOGRAPHY

DARTMOUTH, NS

drawing / dessin: ELECTRICAL POWER AND COMMUNICATIONS

designed / conçu	JS
date	FEBRUARY 2015
drawn / dessiné	RD
date	FEBRUARY 2015
approved / approuvé	
date	
Tender / Soumission	NS
PWGSC Project Manager / Administrateur de projets TPSGC	
project number / no. du projet	R.069793.001
drawing no. / no. du dessin	E101

PWGSC B1 (2004)

E-DRM/GDD-E: 508077