

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions  
Travaux publics et Services gouvernementaux  
Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works and Government Services Canada -**  
**Pacific Region**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British C**  
**V6Z 0B9**

|                                                                                                                                                                             |                                                                                  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|
| <b>Title - Sujet</b><br>CanNor Relocation & Renovation                                                                                                                      |                                                                                  |
| <b>Solicitation No. - N° de l'invitation</b><br>EZ899-160207/A                                                                                                              | <b>Amendment No. - N° modif.</b><br>005                                          |
| <b>Client Reference No. - N° de référence du client</b>                                                                                                                     | <b>Date</b><br>2015-06-29                                                        |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$PWY-019-7526                                                                                                    |                                                                                  |
| <b>File No. - N° de dossier</b><br>PWY-5-38033 (019)                                                                                                                        | <b>CCC No./N° CCC - FMS No./N° VME</b>                                           |
| <b>Solicitation Closes - L'invitation prend fin<br/>at - à 02:00 PM<br/>on - le 2015-07-02</b>                                                                              | <b>Time Zone</b><br><b>Fuseau horaire</b><br>Pacific Daylight Saving<br>Time PDT |
| <b>F.O.B. - F.A.B.</b><br><b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/> |                                                                                  |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Ngan, Ken (PWY)                                                                                              | <b>Buyer Id - Id de l'acheteur</b><br>pwy019                                     |
| <b>Telephone No. - N° de téléphone</b><br>(604) 658-2755 ( )                                                                                                                | <b>FAX No. - N° de FAX</b><br>(604) 775-6633                                     |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b><br>CanNor - Elijah Smith Building - Whitehorse, YT  |                                                                                  |

**Instructions: See Herein**

**Instructions: Voir aux présentes**

|                                                                                                                                                                                                                                                    |                                              |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|
| <b>Delivery Required - Livraison exigée</b>                                                                                                                                                                                                        | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>                                                                                                                                           |                                              |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>                                                                                                                                                                 |                                              |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm<br/>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/<br/>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |                                              |
| <b>Signature</b>                                                                                                                                                                                                                                   | <b>Date</b>                                  |

---

This Solicitation Amendment 005 is raised to provide responses to further questions received.

All other terms and conditions remain unchanged.

Q1.) It appears there are partition system doors and sidelights that we are to reuse. But as I see it they are going into 2x4 walls with 5/8 drywall. Partition systems only fit to 2 1/2 inch stud walls with 1/2 inch drywall, which is what mostly exists in the building for most office walls except where drywall is taped and filled.

A1.) Based on site measurements partition systems are 4" studs with 1/2" drywall. 5/8" drywall will need to be finished cleanly with a J-mold.

Q2.) I also can't find the wall types for the fourth floor.

A2.) Please refer to Addendum No 1.

Q3.) Also on the fourth floor where the fridge is to go. All the plumbing currently runs through the floor in that area. To move them anywhere else the slab will have to be x-rayed at a very big cost as we have done it many times before. Is there any chance of leaving the sink cabinet in current location and moving the fridge?

A3.) Plumbing should be moved within wall cavity only.

End of Solicitation Amendment 005.