

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet CanNor Relocation & Renovation	
Solicitation No. - N° de l'invitation EZ899-160207/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2015-06-29
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7526	
File No. - N° de dossier PWY-5-38033 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-02	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CanNor - Elijah Smith Building - Whitehorse, YT	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Solicitation Amendment 005 is raised to provide responses to further questions received.

All other terms and conditions remain unchanged.

Q1.) It appears there are partition system doors and sidelights that we are to reuse. But as I see it they are going into 2x4 walls with 5/8 drywall. Partition systems only fit to 2 1/2 inch stud walls with 1/2 inch drywall, which is what mostly exists in the building for most office walls except where drywall is taped and filled.

A1.) Based on site measurements partition systems are 4" studs with 1/2" drywall. 5/8" drywall will need to be finished cleanly with a J-mold.

Q2.) I also can't find the wall types for the fourth floor.

A2.) Please refer to Addendum No 1.

Q3.) Also on the fourth floor where the fridge is to go. All the plumbing currently runs through the floor in that area. To move them anywhere else the slab will have to be x-rayed at a very big cost as we have done it many times before. Is there any chance of leaving the sink cabinet in current location and moving the fridge?

A3.) Plumbing should be moved within wall cavity only.

End of Solicitation Amendment 005.