




1 MAIN FLOOR PLAN - LIGHTING LAYOUT
E1.0 SCALE 1/8" = 1' 0"



2 MAIN FLOOR PLAN - POWER AND SYSTEMS LAYOUT
E1.0 SCALE 1/8" = 1' 0"



3 MEZZANINE POWER AND SYSTEMS LAYOUT
E1.0 SCALE 1/8" = 1' 0"



4 MEZZANINE LIGHTING LAYOUT
E1.0 SCALE 1/8" = 1' 0"

SYMBOL SCHEDULE

- Linear luminaire, 'B1-a' denotes panel circuit # and switch.
 - Night light luminaire.
 - Wall mounted luminaire. 'A' denotes type.
 - Single pole switch.
 - Single pole switches in multiple.
 - Photocell by electrical contractor.
 - Duplex receptacle.
 - Duplex receptacle on separate circuit. Provide tamocad label indicating "SC".
 - Duplex receptacle weather proof.
 - 30A-2P dryer receptacle, verify location.
 - Ground fault duplex receptacle.
 - 15A-2P split wired receptacle.
 - Combination voice/data outlet c/w cover plate. Run one(1) 3/4" conduit to accessible ceiling space or crawlspace.
 - Motor. Refer to mechanical for exact location. For roof mounted equipment, supply and install wire and connect a separate circuit GFI receptacle in accordance with C.E.C. rule 26-704.
 - Disconnect switch to suit application. By electrical contractor.
 - Motorized damper control wiring by mechanical contractor, 120V power supply by electrical contractor.
 - Junction box.
 - Electric heater, "C" denotes type, see electric heating schedule. "1000" denotes watts.
 - denotes heater c/w built in thermostat. ○ denotes heater controlled by remote thermostat. Provide low voltage relays if required. Refer to mechanical for details.
 - LED Emergency double head fixture c/w two(2) 6W (540 lumen) LED heads. Wire to battery bank. Lumacel.
 - Combination LED pictogram egress sign/emergency double head fixture c/w two(2) 6W (540 lumen) LED lamps and integral battery backup (minimum 30 minutes). Lumacel.
 - Underground service point. Co-ordinate location with SaskPower prior to rough-in. Run main feeders to utility preferred location. Provide weatherproof customer service termination enclosure, protection shield, trenching, backfilling, etc. Obtain utility contribution charges from utility for owner.
- Note:
"E" indicates existing to remain.
"R" indicates existing electrical device relocated to new location indicated.

MOTOR SCHEDULE								
NO.	DESCRIPTION	LOCATION	VOLTAGE	HP/W/MCA	C.B.	COND.	STARTER	NOTES
RH1,2,3	RADIANT HEATER	SEE SITE PLAN	120V-1PH	1.5A	15A-1P	#12	-	1,5
OAC	OFFICE AIR CONDITIONING UNIT	ROOF (OUTDOOR UNIT) OFFICE (INDOOR UNIT)	208V-1PH 208V-1PH	1.3MCA 1MCA	20A-2P 15A-2P	#12	-	1
AS	ANTI-STRATIFICATION FAN	SEE SITE PLAN	120V-1PH	-	-	#12	-	1
EF1	EXHAUST FAN	GARAGE	120V-1PH	1/3 HP	20A-1P	#12	MAGNETIC	1,2
EF2	EXHAUST FAN	GARAGE	208V-3PH	7.5 HP	70A-3P	#3	MAGNETIC	1,2
MD1	MOTORIZED DAMPER	GALLERY	120V-1PH	FRAC.	15A-1P	#12	-	1
GD1	CARBON MONOXIDE/NITROGEN DIOXIDE DETECTOR	SEE SITE PLAN	120V-1PH	-	15A-1P	#12	-	1

SPECIFIC NOTES:
1. WIRE AND CONNECT AS REQUIRED. REFER TO MECHANICAL.
2. MAGNETIC STARTER BY ELECTRICAL CONTRACTOR.
3. MANUAL STARTER BY ELECTRICAL CONTRACTOR.
4. COORDINATE INSTALLATION OF PATHWAYS TO PIT FOR SUMP PUMP WIRING.
5. WIRE AND CONNECT INDOOR UNIT TO TERMINALS S1 AND S2 ON OUTDOOR UNIT.

GENERAL NOTES:
A. MANUAL STARTERS TO BE C/W OVERCURRENT PROTECTION.
B. ALL DISCONNECT SWITCHES TO BE SUPPLIED BY ELECTRICAL CONTRACTOR.
C. ELECTRICAL CONTRACTOR TO PROVIDE CIRCUIT BREAKERS AND WIRING ACCORDING TO THE FINAL NAMEPLATES OF ALL THE MECHANICAL EQUIPMENT.
D. ALL LOW VOLTAGE CONTROL WIRING BY MECHANICAL CONTRACTOR.
E. ALL LINE VOLTAGE CONTROL WIRING BY ELECTRICAL CONTRACTOR - REFER TO MECHANICAL SECTION. CO-ORDINATE EXACT REQUIREMENTS WITH MECHANICAL CONTRACTOR.

SPECIFIC ELECTRICAL NOTES

1. RELOCATE EXISTING ELECTRICAL DEVICE TO LOCATION INDICATED. EXTEND, REROUTE WIRING AS REQUIRED.
2. WIRE AND CONNECT OVERHEAD DOOR OPERATOR AS PER MANUFACTURERS RECOMMENDATIONS. CONFIRM EXACT REQUIREMENTS.
3. BOND FIRE CABINET WIRE TO BUILDING GROUND.
4. WIRE AND CONNECT EXISTING DISTRIBUTION TO NEW ELECTRICAL SERVICE. EXTEND, REROUTE WIRING AS REQUIRED.
5. DISCONNECT AND REMOVE EXISTING ELECTRICAL SERVICE ENTRANCE.
6. WIRE AND CONNECT OWNERS EQUIPMENT AS PER MANUFACTURERS RECOMMENDATIONS. CONFIRM EXACT REQUIREMENTS ON SITE.
7. WIRE AND CONNECT INDOOR UNIT TO OUTDOOR UNIT. REFER TO MECHANICAL.
8. SEALABLE TO UTILITY'S SATISFACTION.

WET AND HAZARDOUS LOCATION ELECTRICAL NOTES

1. ALL WIRING IN SERVICE AREAS INDICATED TO COMPLY WITH C.E.C. 20-102. AREA FROM FINISHED FLOOR TO 50mm ABOVE FINISHED FLOOR TO BE HAZARDOUS AREA CLASS 1 ZONE 2. AREA BELOW FLOOR TO BE HAZARDOUS AREA CLASS 1 ZONE 1.
2. ALL WIRING IN WET LOCATION TO BE IN COMPLIANCE WITH C.E.C. 22-002 CATEGORY 1.
3. ALL LIGHTING TO BE LENSED. CONFIRM PRIOR TO ORDERING.

GENERAL ELECTRICAL NOTES

1. SECURITY WIRING BY OWNER.


LUMINAIRE SCHEDULE				
TYPE	DESCRIPTION	MOUNTING	CATALOG NUMBER	LAMPS
A	I-BEAM LED, 16"x45", WITH 12,000 NOMINAL LUMENS, NARROW DISTRIBUTION, AND 4000K 70 CRI LEDS, DLC CERTIFIED	MOUNTED AT 17'	LITHONIA LIGHTING IBL-12L-ND-LP740DLC	125W LED
B	4' STRIPLIGHT WITH DIFFUSE LENS 5000LM 80CRI 4000K	MOUNTED AT 8.8'	LITHONIA LIGHTING ZLIN-L48-5000LM-FST-MVOLT-4 OK-80CRI-WH	43W LED
C	GTL 2"x4', 4800 NOMINAL LUMENS, A12 LENS, 4000K	MOUNTED AT 9'	LITHONIA LIGHTING 2GTL-4-48L-EZ1-LP840	47W LED
D	D-SERIES SIZE 2 LED WALL LUMINAIRE	WALL MOUNTED	DSKW2-LED-30C-700K-40K-14M-MVOLT-DBXD	71W LED
E	HIGH-PRESSURE HOSE-DOWN FHE LED	MOUNTED AT 17'	FHELED-12L-FST	152W LED

LUMINAIRE SCHEDULE NOTES:
1. ALL FLUORESCENT BALLAST TO BE ELECTRONIC. MB HYDRO "POWER SMART" APPROVED.
2. ALL FLUORESCENT LAMPS TO BE 3500K & 85 CRI, UNLESS OTHERWISE NOTED.
3. PROVIDE PHOTOCCELL CONTROL FOR ALL OUTDOOR LUMINAIRES.

HEATING SCHEDULE					
TYPE	WATTS	VOLTAGE	DESCRIPTION	CATALOGUE NO.	NOTES
B	750	120	BASEBOARD	QUELLET ODB0752	1
C	1000	120	BASEBOARD	QUELLET ODB1002	1

SPECIFIC HEATING NOTES:
1. C/W BUILT-IN THERMOSTAT OR WIRED TO REMOTE THERMOSTAT AS SHOWN ON DRAWINGS.
2. RECESSED UNLESS OTHERWISE INDICATED. C/W BUILT-IN THERMOSTAT UNLESS OTHERWISE INDICATED.
3. C/W BUILT-IN THERMOSTAT. MOUNT SECURELY WHERE INDICATED TO THE SATISFACTION OF THE ENGINEER.

GENERAL HEATING NOTES:
A. VOLTAGE TO BE AS INDICATED ABOVE UNLESS OTHERWISE NOTED ON DRAWINGS.



* SIZE CIRCUIT BREAKER AND WIRING ACCORDING TO THE FINAL NAMEPLATE RATING ON THE EQUIPMENT.
NOTE: DASHED INDICATES EXISTING.

PANEL MOUNTING LOCATION	'C' SURFACE GALLERY 202	VOLTAGE 120/208V-3PH-4W		REMARKS	
		MAIN BUS 400A	REMARKS	C/W DOOR	DESCRIPTION
EXTERIOR LIGHTING	15 1	20	DRILL *		
LIGHTING	15 3	4			
LIGHTING	15 5	6 15	BANDSAW *		
LIGHTING	15 7	8 30	HOIST *		
BASEBOARD HEATER	15 9	10	#10 WIRE		
RECEPTACLES	15 11	12 50	PLASMA CUTTING STATION *		
RECEPTACLES	15 13	14	#8 WIRE		
RECEPTACLES	15 15	16 20	DRILL *		
RECEPTACLES	15 17	18			
SPLIT WIRED RECEPTACLE	15 19	20 30	LATHE *		
SPLIT WIRED RECEPTACLE	15 21	22	#10 WIRE		
SPLIT WIRED RECEPTACLE	15 23	24			
SPLIT WIRED RECEPTACLE	15 25	26 15	MILLING MACHINE *		
SPLIT WIRED RECEPTACLE	15 27	28 30			
SPLIT WIRED RECEPTACLE	15 31	32 30	AIR COMPRESSOR *		
SC RECEPTACLE	15 33	34	#10 WIRE		
SC RECEPTACLE	15 35	36			
SC RECEPTACLE	15 37	38 15	HAUSSFELD BENDER *		
SC RECEPTACLE	15 39	40			
SC RECEPTACLE	15 41	42			
SC RECEPTACLE	15 43	44 15	IRON FABRICATION TOOL *		
WP GF RECEPTACLE	15 45	46			
O/H DOOR *	15 47	48			
O/H DOOR *	15 49	50 15	50T SHOP PRESS *		
O/H DOOR *	15 51	52			
O/H DOOR *	15 53	54			
O/H DOOR *	15 55	56 15	GRINDER *		
O/H DOOR *	15 57	58			
O/H DOOR *	15 59	60 15	FILTER CRUSHER *		
MD1	15 63	64 15	POWER WASHER (FUTURE) *		
GD1	15 65	66			
RH1	15 67	68 30	DRYER		
RH2	15 69	70	#10 WIRE		
RH3	15 71	72 15	SC RECEPTACLE		
OAC	20 73	74 200	EXISTING SHOP DISTRIBUTION		
EF1	20 75	76	4#3/0 R90 IN 2"C		
EF2	20 77	78			
EF2	20 79	80 15	AS (x2)		
#3 WIRE	81	82 15	SPARE		
SPARE	83	84 15	NIGHT LIGHTING/EMERGENCY LIGHTING		
SPARE	100 85	86	SPACE		
SPARE	87	88	SPACE		
SPARE	89	90	SPACE		

* SIZE CIRCUIT BREAKER AND WIRING ACCORDING TO THE FINAL NAMEPLATE RATING ON THE EQUIPMENT.


ASSOCIATION OF PROFESSIONAL ENGINEERS OF SASKATCHEWAN
CERTIFICATE OF AUTHORIZATION
 NOVA 3 ENGINEERING LTD.
 NUMBER 752
 PERMISSION TO CONSULT HELD BY
 DISCIPLINE: ELECTRICAL
 SIGNATURE: [Signature]

NOVA 3 ENGINEERING LTD.
 CONSULTING ENGINEERS
 2111-120 FORT STREET TEL: (204) 943-6142
 WINNIPEG, MANITOBA R3C 1C7 FAX: (204) 942-1276
 WWW.NOVA3.CA JLN: 351506
 THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NOVA 3 ENGINEERING LTD. AND MAY ONLY BE REPRODUCED WITH THE WRITTEN PERMISSION OF NOVA 3 ENGINEERING LTD.
 THE CONCEPT AND DESIGN INCORPORATED INTO THIS DRAWING ARE BASED ON INFORMATION PROVIDED BY THE CLIENT AND OTHER RELATED SOURCES. PROFESSIONAL ENGINEER ACCEPTS NO RESPONSIBILITY FOR DRAWING AND DESIGN UNLESS DRAWING IS ACCOMPANIED BY ORIGINAL SEALED LETTER OF WRITING OR EQUIVALENT ACCEPTABLE FACSIMILE. PROFESSIONAL ENGINEER ACCEPTS NO RESPONSIBILITY FOR FINAL INSTALLATION CONFORMANCE WITHOUT ORIGINAL SEALED CERTIFICATE OF INSPECTION OR EQUIVALENT ACCEPTABLE FACSIMILE.

Carcoana ARCHITECTURE LTD.

Lawrence N. Carcoana, Principal
 SAA, AAA, MAA, AIA, NCAARB
 1457 ALBERT STREET, REGINA, SASKATCHEWAN S4S 2R8
 TEL: 306.565.0411 FAX: 306.757.9471
 larry.carcoana@myaccess.ca

McCinn Engineering Ltd.
 A DIVISION OF MCCINN GROUP
 1457 ALBERT STREET, REGINA, SASKATCHEWAN S4S 2R8
 TEL: 306.565.0411 FAX: 306.757.9471
 mcginn@mccinngroup.ca www.mccinngroup.ca



Project Title:
AAFC - B107 ADDITION

INDIAN HEAD, SK

Any representations in the tender documents are for the general information of bidders and are not in any way warranted or guaranteed by or on behalf of the owner or the owner's consultants and its subcontractors' employees, and neither the owner nor its consultants or its employees, shall be liable for any representations negligent or otherwise contained in the documents. These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any party with whom the contractor shall check all dimensions, elevations and other data as represented on all drawings in the set for consistency and correctness and report to the consultant any discrepancies prior to proceeding with construction. Any costs to the contractor arising from failure to execute this requirement is a cost to the contractor and not the owner nor the consultant. This term supercedes the specifications. All construction work to be completed in accordance with all applicable code and requirements of all utilities as set out by governing authorities.

Issue Record:
 YY.MM.DD/Issued For/Issued To/Issued By
 Revisions:
 R# Brief Description/YY.MM.DD/Revised By

ELECTRICAL - LIGHTING, POWER AND SYSTEMS

Designed By: AJT Scale: AS INDICATED
 Drawn By: EC Date: MAY 2015
 Checked By: VJT Date: 2015.06.01
 Project No.: **4810**

E1.0

Revision No.: R# Date: YYYY.MM.DD
 Issued For: **BUILDING PERMIT/TENDER**
 Date Issued: 2015.06.01
 Date Plotted: 2015.06.01