



Materiel and Procurement Services
200 Kent Street, Station 9W067
Ottawa, Ontario
K1A 0E6

FP802-150068

July 7, 2015

Title: Floating Breakwater, Arnold's Cove, NL

ADDENDUM: NO. 1

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Thursday July 17, 2015
Time: 2:00 Hours (2:00 pm) Eastern Daylight Time
No: FP802-150068

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS

.1 Add:

Add the following drawings to the Tender documents:

C1 of 1 – Floating Breakwater – End & Side Views

Bidders are advised that all work associated with this addition shall be included in the bid price for this work.

Bidder shall include all plant, equipment, materials and labour.

.2 Issued for the Detailing of the Addition of Extra Flotation:

.1 Bidders are advised that two (2) additional flotation pipes are to be added to the floating breakwater as per the attached drawing.

By submission of its bid, the bidder confirms that it has read and understands the requirements expressed in all addenda and has included all cost of these requirements in its total bid amount.

All other terms and conditions remain unchanged.

Thank you,

Natasha Blackstein

Contracting Officer,

Materiel and Procurement Services

Fisheries and Oceans Canada,


200 Kent Street, Station 9W067

Ottawa, ON K1A 0E6

Tel: (613) 993-5741


Email: natasha.blackstein@dfo-mpo.gc.ca

NO.	REVISION	DATE
0	STRUCTURE #1	15/07/15
PROJECT FLOATING BREAKWATER CONSTRUCTION ARNOULD'S COVE, N.L.		
DRAWN BY CHECKED BY APPROVED BY DATE		
PROJECT NUMBER 721444		
SHEET NO. C1 OF 1		



300mm Ø HOPE DRIZELS PER MASS PILES C/W
 BUTT PILING END CAPS, TWO (2) ADDITIONAL
 HOLD DOWN CLAMPS PER PIPE. SEE DETAILS ON
 TENDER DRAWINGS.

LEGEND
 FULL TIMBER
 BLOCKING



300mm Ø HOPE DRIZELS PER MASS PILES C/W
 BUTT PILING END CAPS, TWO (2) ADDITIONAL
 HOLD DOWN CLAMPS PER PIPE. SEE DETAILS ON
 TENDER DRAWINGS.

