



Daniel Haché  
Project Manager  
Public Works and Government Services Canada  
111 Wellington Street  
Ottawa, ON K1A 0S5

16 September 2013

**SUBJECT: Addendum to the Designated Substance Survey prepared for the Centre Block Major Rehabilitation Project.**

To Whom It May Concern,

The Designated Substances Survey that was prepared for the Centre Block Major Rehabilitation Project concluded that fecal matter droppings were not present in the building, nor suspected of being present, in forms or quantities that would either impact future work or pose risks to human health or the environment. Contrary to these findings it is known that there are quantities of pigeon debris on the exterior masonry of the building.

Although excrement is not classified as a designated substance, care should be taken during its removal. It is recommended to use the cleaning methods identified in Appendix B: Procedures for Cleanup of Bird and Bat Droppings of the Environmental Abatement Council of Ontario's (EACO) Mould Abatement Guidelines.

Sincerely,

Christopher Robinson  
Environmental Advisor,  
Environmental Services Directorate, Professional and Technical Services Management  
Real Property Branch, PWGSC

Environmental Services Directorate (ESD) is committed to quality through the provision of consistent, high quality services throughout all of its programs. To this end, ESD has developed and implemented a Quality Management System (QMS) based on the principles of ISO 9001. We have standardized our QMS requirements for project and program delivery, and implemented specific guidelines and procedures for effective planning, operation and control of our service lines.