

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Radar Hill Viewpoint Shelter	
Solicitation No. - N° de l'invitation EZ899-160310/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2015-07-09
GETS Reference No. - N° de référence de SEAG PW-\$PWY-022-7533	
File No. - N° de dossier PWY-5-38035 (022)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-16	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Arthur (PWY), Carolyn	Buyer Id - Id de l'acheteur pwy022
Telephone No. - N° de téléphone (604) 775-6667 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Pacific Rim National Park - Tofino, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-160310/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWY-5-38035

Buyer ID - Id de l'acheteur

pw022

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Amendment 004

This Amendment 004 is raised to :

1) incorporate Addendum 3.

1) Please see attached Addendum 3.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

Radar Hill, BC
Radar Hill Viewing Shelter
2015-07-08

ADDENDUM #3

Page 1 of 1

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

ADDENDUM No. 3

This Addendum contains 1 pages, 0- 8 ½" x 11 ½" and 0-11"x17" sketches

Amend/revise the Standard Contract Documents as follows:

RESPONSE TO CONTRACTOR QUERIES

- 1.0 Question: How many feet of new concrete curb 250 wide is required between the two new decks?

Answer: Along perimeter of concrete slab where there are no existing concrete curb, provide 250 wide x300 long new concrete curb @2.3M maximum at beam support as per section 3/201 & section 3/203 of new concrete curb at Top South Platform and Lower North East Platform.

- 2.0 Question: Are we to assume there is existing concrete slab under all decking?

Answer: Assume there is an existing concrete slab throughout except ramp strip area, typical.

- 3.0 Question: What type of wood is to be used for the new wood curb and beam 152x152?
Treated? Cedar?

Answer: New wood curb and beam 152x152 shall be Cedar No. 1.

- 4.0 Question: What is the surface of the decking to be? Rough? Sawn? Plane?

Answer: The decking shall be of Sawn surface.

END OF ADDENDUM No .3
