

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works & Government  
Services Canada/Réception des souissions Travaux  
publics et Services gouvernementaux Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax,(N.E.)**  
**B3J 1T3**  
**Halifax**  
**Bid Fax: (902) 496-5016**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.E.)  
B3J 3C9  
Halifax  
Nova Scot

<b>Title - Sujet</b> Renovations Fit Up - BIO Argo Bldg.	
<b>Solicitation No. - N° de l'invitation</b> EB144-160279/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EB144-16-0279	<b>Date</b> 2015-07-10
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWA-121-5253	
<b>File No. - N° de dossier</b> PWA-5-74031 (121)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-16</b>	<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Russell (PWA), Alex	<b>Buyer Id - Id de l'acheteur</b> pwa121
<b>Telephone No. - N° de téléphone</b> (902) 496-5168 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Amendment 002 is raised for the following:**

**Revisions to Specifications and Drawings - as per Addendum #1 (attached)**

**Revisions to incorporate changes to the PWGSC Integrity Policy - as per below.**

**“PWGSC`s New Government-wide Integrity Regime Takes Effect Immediately – Active PWGSC issued tender notices that are closing July 3rd, and from July 6th to July 10th, will have their closing dates extended. To find the new closing dates, please check the individual tender you are following. You may also click the Amended Today icon and look for tender notices where PWGSC is the procurement entity. To learn more, please read New PWGSC Implementation of Government-wide Integrity Regime Announced on July 3, 2015”**

#### **At SI02BID DOCUMENTS**

*Delete* in its entirety.

*Insert* the following:

1. The following are the bid documents:

- a. Invitation to Tender - Page 1;
- b. Special Instructions to Bidders;
- c. General Instructions - Construction Services - Bid Security Requirements R2710T **(2015-07-03)**
- d. Clauses & Conditions identified in “Contract Documents”;
- e. Drawings and Specifications;
- f. Bid and Acceptance Form and related Appendix(s); and
- g. Any amendment issued prior to solicitation closing.

Submission of a bid constitutes acknowledgement that the Bidder has read and agrees to be bound by these documents.

2. General Instructions - Construction Services - Bid Security Requirements R2710T is incorporated by reference and is set out in the Standard Acquisition Clauses and Conditions (SACC) Manual, issued by Public Works and Government Services Canada (PWGSC). The SACCManual is available on the PWGSC Web site:

<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R>

**At CONTRACT DOCUMENTS (CD)***Delete* in its entirety.*Insert* the following:

## 1. The following are the contract documents:

- a. Contract Page when signed by Canada;
- b. Duly completed Bid and Acceptance Form and any Appendices attached thereto;
- c. Drawings and Specifications;
- d. General Conditions and clauses

GC1 General Provisions – Construction Services	R2810D	<b>(2015-07-03);</b>
GC2 Administration of the Contract	R2820D	(2015-02-25);
GC3 Execution and Control of the Work	R2830D	(2015-02-25);
GC4 Protective Measures	R2840D	(2008-05-12);
GC5 Terms of Payment	R2850D	(2015-02-25);
GC6 Delays and Changes in the Work	R2860D	(2013-04-25);
GC7 Default, Suspension or Termination of Contract	R2870D	(2008-05-12);
GC8 Dispute Resolution	R2880D	(2015-04-01);
GC9 Contract Security	R2890D	(2014-06-26);
GC10 Insurance	R2900D	(2008-05-12);

Allowable Costs for Contract Changes Under GC6.4.1 Supplementary Conditions	R2950D	(2015-02-25);
--	--------	---------------

- e. Any amendment issued or any allowable bid revision received before the date and time set for solicitation closing;
- f. Any amendment incorporated by mutual agreement between Canada and the Contractor before acceptance of the bid; and
- g. Any amendment or variation of the contract documents that is made in accordance with the General Conditions.

## 2. The documents identified by title, number and date above are incorporated by reference and are set out in the Standard Acquisition Clauses and Conditions (SACC) Manual, issued by Public Works and Government Services Canada (PWGSC). The SACC Manual is available on the PWGSC Web site:

## 3. The language of the contract documents is the language of the Bid and Acceptance Form submitted.

***All other terms and conditions remain the same.***

## Addendum No.1

Additional Specification Sections to be added:

1. 12 24 00 Window coverings
2. 08 50 00 Aluminum Windows
3. 20 21 13 Plastic Toilet Compartments

Specific to the exterior paint system and the custodial shelf:

Spec Section 09 91 13 Exterior Painting

Article 2.4. Exterior Painting systems p. 9

Add 2.4.4. Paint for existing metal siding:

- .1 One coat DevFlex 4020 @ 5 to 7 mils DFT. Two coat of Dulux Diamond Exterior 1640 @ 2 to 3 mils DFT per coat.
- .2 One brushed stripe coat SSPC-PL-ACS1. to all edges, welds, bolts, nuts per WFT and atmospheric conditions contained in manufacturers TDS. Two coats of Benjamin Moore's Ultra Spec High Performance Direct To Metal FP28 Acrylic Gloss Enamel
- .3 One coat Devoe epoxy primer (ICI 205) @ 5 to 7 mils DFT. Two coats acrylic urethane (ICI 379) @ 2 to 3 mils DFT per coat.

Spec Section 10 28 10 Toilet and Bath Accessories:

T10 - Custodial Utility Shelf

T8- Mop and broom holder:

Surface-mounted; stainless steel with satin finish;

Shelf: 18 gauge, 36" long, 4 anti-slip mop holders, 3 rag hooks.

.1 Acceptable material:

- .1 Bobrick B-239x34.
- .2 Bradley 9953.
- .3 ASI Watrous 1308-4.