

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Radar Hill Viewpoint Shelter	
Solicitation No. - N° de l'invitation EZ899-160310/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client	Date 2015-07-10
GETS Reference No. - N° de référence de SEAG PW-\$PWY-022-7533	
File No. - N° de dossier PWY-5-38035 (022)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-16	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Arthur (PWY), Carolyn	Buyer Id - Id de l'acheteur pwy022
Telephone No. - N° de téléphone (604) 775-6667 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Pacific Rim National Park - Tofino, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-160310/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

005

File No. - N° du dossier

PWY-5-38035

Buyer ID - Id de l'acheteur

pw022

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Amendment 005

This Amendment 005 is raised to :

1) incorporate Addendum No. 4.

1) Please see attached Addendum No. 4.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

Radar Hill, BC
Radar Hill Viewing Shelter
2015-07-09

ADDENDUM #4

Page 1 of 1

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

ADDENDUM No. 4

This Addendum contains 1 page, 0- 8 ½" x 11 ½" and 0-11"x17" sketch

Amend/revise the Standard Contract Documents as follows:

CHANGES AND CLARIFICATIONS

DRAWINGS

1.0 DWG S301

- 1.1 **Revise** the dimension of metal flashing all around that covers the wood fascia from 50 to 75, typical on side view section A/-.

2.0 DWG S302

- 2.1 **Revise** the dimension of metal flashing all around that covers the wood fascia from 50 to 75, typical on section 2/302.

RESPONSE TO CONTRACTOR QUERIES

- 1.0 Question: Lower North East platform, is the existing wood bench and planter box wall to be removed?
Answer: The existing wood bench and planter box wall to be removed of Lower North East platform. Install new wood bench as per drawings. New planter box matching existing shall be installed.
- 2.0 Question: Is there an existing slab under the south platform, under planter and wood bench, that is to be removed? If not are we to provide new slab? (Aprox 305 Thick)
Answer: Assuming there is an existing slab under the south platform, under planter and wood bench.

END OF ADDENDUM No .4
