

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Wharf Reconstruction-Pigeon Hill,NB	
Solicitation No. - N° de l'invitation EC015-160520/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.077953.001	Date 2015-07-13
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3648	
File No. - N° de dossier PWB-5-38035 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-16	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EC015-160520/A

Client Ref. No. - N° de réf. du client

R.077953.001

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWB-5-38035

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment No. Four (4) is raised to include the following addendum no. 4.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 4

1. Clarification

Revise Section 01 14 10, paragraph 1.2 Scheduling and Management of Work, to read ,

.2 The Contractor is advised that a lobster fishery is in effect from early May to end of June and a herring fishery from early August to mid September. Fishermen, fish buyers, traffic will be utilizing surrounding structures on a regular basis.

.1 As a minimum, the contractor must have the following work completed:

.1 100% by July 31, 2016.

2. QUESTIONS AND ANSWERS

Q1: Plan E1 of 4; Note #2 - What is ``1-100M``?

A1: Plan E1 of 4; Note 2 – delete the reference to “1-100m”.

Q2: Plan E1 of 4; Detail #4: On Lighting Control Detail, what is the “Figure 4” referring to on the circuits #A4, #A8 and #A12?

A2: Plan E1 of 4; Detail 4 - Note 4 refers to a junction box to separate two (2) circuits.

Q3: Plan E1 of 4; Note #13: Please clarify “2 runs of 3#300mcm in one pipe”

A3: Plan E1 of 4; Note 13 - It is two(2) runs of (3#300MCM & 1#3/0 gnd RW90 in 103mm PVC) as per trench detail ‘A-A’ - use spare duct as second conduit.

Q4: Plan E1 of 4; Detail #1 Trench B-B: What is 3#500mcm?

A4: Plan E1 of 4; Detail 1 trench ‘B-B’: 3#500MCM- delete this reference and only use Trench ‘B-B’ on secondary branch circuits from Panel A.