

							
							
<b>ISSUED FOR TENDER</b> 0		<b>REVISED</b> 0		<b>DATE</b> 0		<b>PROJECT</b> 0	
<b>HARBOUR DEVELOPMENT</b> <b>JOE BATT'S ARM, NL</b>				<b>DEMOLITION</b> <b>SITE PLAN</b>			
drafter: K.N. date: MAY 2015		drafter: B.C. date: MAY 2015		drafter: B.C. date: MAY 2015		drafter: B.C. date: MAY 2015	
approved: K.N. date: MAY 2015		approved: B.C. date: MAY 2015		approved: B.C. date: MAY 2015		approved: B.C. date: MAY 2015	
Project number: <b>R.077427.001</b>				drawing no.: <b>E1</b>			

**GENERAL NOTES:**

- ALL WORK TO BE IN ACCORDANCE WITH THE LATEST REQUIREMENTS OF THE NATIONAL BUILDING CODE OF CANADA, LATEST EDITION; CANADIAN ELECTRICAL CODE, CURRENT EDITION; ANY OTHER AUTHORITIES HAVING JURISDICTION.
- CONTRACTOR TO PROVIDE ALL CUTTING, PATCHING AND PAINTING TO MATCH EXISTING. SEE SPECIFICATION FOR DETAILS. COORDINATE ON SITE.
- CONTRACTOR MUST VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE BEFORE PROCEEDING WITH ANY PART OF THIS WORK. DO NOT SCALE FROM DRAWINGS. CONTRACTOR TO VERIFY WORK AREA IN ADVANCE WITH DEPARTMENTAL REPRESENTATIVE FOR COORDINATION OF RELATED DAILY WORK SCHEDULES AND PARKING.
- CONTRACTOR SHALL BE RESPONSIBLE FOR CLEAN UP AND DISPOSALS OF WORK AREA ON A DAILY BASIS. AFTER EACH WORKING SHIFT WORK AREA TO BE CLEANED AND FREE OF DEBRIS.
- ALL WIRING TO BE INSTALLED IN CONDUIT AS INDICATED.
- ACCESS TO FACILITY TO BE COORDINATED WITH DEPARTMENTAL REPRESENTATIVE.
- LABEL ALL EQUIPMENT WITH LAMACOID TAGS AS PER SPECIFICATION.
- ALL EXISTING ELECTRICAL EQUIPMENT REMOVED TO BE TURNED OVER TO DEPARTMENTAL REPRESENTATIVE. IF DEPARTMENTAL REPRESENTATIVE REFUSES THEN CONTRACTOR TO REMOVE FROM SITE AND DISPOSE.

**ELECTRICAL LEGEND**

- ⊙ HD LIGHTING FIXTURE TO BE KEENE #S13070MALL1 OR APPROVED EQUAL. SEE SPEC.
- ⊙ FLOURESCENT LIGHTING FIXTURE TO BE CFI #VTS248-VX C/W POLYCARBONATE LENS OR APPROVED EQUAL. SEE SPEC.
- ⊙ SINGLE POLE TOGGLE SWITCH, 15 AMP, 120 VOLT, YELLOW, MARINE GRADE C/W PVC MARINE GRADE COVERPLATE. SEE SPEC. FOR MORE INFORMATION. MOUNT 1200mm ABOVE FINISHED FLOOR.
- ⊙ LINE VOLTAGE THERMOSTAT RATED 240 VOLT, 4500 WATTS, DPST, WHITE. MOUNT 1200mm AFF.
- ⊙ SURFACE MOUNTED PANELBOARD
- ⊙ LIGHT POLE AND FIXTURES. SEE DETAIL ON DRAWING E4.
- ⊙ ELECTRICAL PEDESTAL. SEE DETAILS ON DRAWING E3.
- ⊙ DUPLEX U-GROUND RECEPTACLE, 120 VOLT, 15 AMP, MARINE GRADE, YELLOW & C/W PVC MARINE GRADE COVERPLATE. WALL MOUNT 400mm ABOVE FINISHED FLOOR. "WP" INDICATES WEATHERPROOF GASKET AND COVERPLATE.
- ⊙ ELECTRIC HEATER.
- ⊙ JIB CRANE

