

PN: R.077427.001
Harbour Development
Joe Batt's Arm, NL

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- .1 Section Includes:
1. Lighting.
- .2 Related Sections:
1. Division 01 - Submittal Procedures.
 2. Division 01 - Quality Requirements

1.3 SCOPE

.1 Light fixtures in harbor authority shed shall be supplied and installed by this Contractor. Light fixtures on wooden poles to be supplied by Owner and installed by this Contractor.

1.4 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings in accordance with Division 01 - Submittal Procedures.
- .2 Submit shop drawings for ballasts.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Type A fixture:
1. Rated 120 V, 60 Hz, 32 W fluorescent lamp, constructed of one piece fiberglass reinforced polyester housing. CSA listed for damp/wet locations and complete with polycarbonate acrylic lens.
2. Type B fixture:
1. Rated 120 V, 60 Hz, 70 Watt metal halide lamp. Constructed of die cast aluminum, CSA listed for wet location.

2.2 SPARES

- .1 Provide the following spare materials, turn over to Canada prior to completion:
1. Two (2) lamps of each type used on the project.
 2. Two (2) spare ballasts of each type used on the project.

PN: R.077427.001
Harbour Development
Joe Batt's Arm, NL

LIGHTING

Section 26 50 00

Page 2

2015-02-02

PART 3 - EXECUTION

3.1 INSTALLATION

.1 Locate and install fixtures as indicated on drawings.

3.2 WIRING

.1 Connect light fixtures to circuits as indicated.

.2 Perform tests in accordance with Section 26 05 01 - Common Work Results - Electrical.