



Materiel and Procurement Services  
200 Kent Street, Station 9W079  
Ottawa, Ontario  
K1A 0E6

**FP802-150042**

**July 13, 2015**

**Subject: Invitation to Tender: FP802-150041**

**Title: Wharf Construction Repairs, Cowichan Bay, British Columbia**

**ADDENDUM: NO. 03**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum #03 is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: Tuesday, July 21, 2015**

**Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)**

**RFP File No: FP802-150041**

---

**QUESTIONS and ANSWERS– Resulting from Bidders submitted questions**

**1. Question from Bidder:**

Will it be the responsibility of DFO to ensure access to work areas for a marine derrick? Including moving vessels and floating dock structures prior to the contractor's arrival?

**DFO Answer 01:**

Upon submission of a request from the awarded Contractor, the Harbour Authority will make all attempts to accommodate the request.

**2. Question from Bidder:**

How long can we stop access on the dock if we are working on it with equipment?

**DFO Answer 02:**

The wharf structure can be temporarily shut down to accommodate the necessary works. Contractors are to minimize shut downs as much as possible. Awarded Contractor is to submit a proposed schedule to the Harbour Authority prior to commencing work.



**3. Question from Bidder:**

Fall/Winter low tides are at night. Do we have noise restrictions?

**DFO Answer 03:**

The preferred work hours are from 7am to 7pm week days. DFO SCH will consider proposed alternate hours if submitted with the awarded contractors schedule.

**4. Question from Bidder:**

There is a very good chance the cast in place concrete will crack with the jacking loads. What do you want to do about that?

**DFO Answer 04:**

Minor cracks are acceptable and will be the responsibility of the contractor to fill with approved concrete crack filler. Major cracks will not be accepted.

**All other Terms and Conditions for this requirement remain unchanged.**

Regards,

**Lynda Coulombe**

Senior Procurement Officer

Tel: (613) 993-2839

E-mail: [Lynda.Coulombe@dfo-mpo.gc.ca](mailto:Lynda.Coulombe@dfo-mpo.gc.ca)