



Materiel and Procurement Services
200 Kent Street, Station 9W079
Ottawa, Ontario
K1A 0E6

FP802-150042

July 16, 2015

Subject: Invitation to Tender: FP802-150041

Title: Wharf Construction Repairs, Cowichan Bay, British Columbia

ADDENDUM: NO. 04

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum #04 is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Tuesday, July 21, 2015

Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)

RFP File No: FP802-150041

QUESTIONS and ANSWERS– Resulting from Bidders submitted questions

1. Question from Bidder:

It appears the owner is not supplying any of the cap/corbel/pile connection brackets or necessary bolt hardware. The brackets on the plans are 12 x 75 x 700 both sides which is upwards of 220 brackets and upwards of 440 bolts. This is not listed on owner supply list.

DFO Answer 01:

Brackets and bolts for this item are to be supplied by the Contractor. Quantities are to be confirmed by the Contractor.

2. Question from Bidder:

In bent 33 – where does the new cap start and stop? It appears to start at C and go to G.

DFO Answer 02:

The new section is from Bent 33 from F to G and will require a corbel at Pile F

3. Question from Bidder:

What is the tender performance and security required?



DFO Answer 03:

Please reference the following (also stated on the Construction Tender Form) links:

Section 1. TENDER DOCUMENTS

1.2. DFO Instructions to Bidders - Construction at <http://www.dfo-mpo.gc.ca/contract-contrat/instructions-instructions-eng.htm>

1.3. DFO General Conditions - Construction at <http://www.dfo-mpo.gc.ca/contract-contrat/general-generale-eng.htm>

Sub-sections: GI09 Bid Security Requirements and GI21 Performance Evaluation

All other Terms and Conditions for this requirement remain unchanged.

Regards,

Lynda Coulombe
Senior Procurement Officer
Tel: (613) 993-2839
E-mail: Lynda.Coulombe@dfo-mpo.gc.ca