

## **PART 1 GENERAL**

### **1.1            RELATED SECTIONS**

- .1        Section 01 33 00 – Submittal Procedures.
- .2        Section 26 05 00 – Common Work Results – Electrical.

### **1.2            SUBMITTALS**

- .1        Submit shop drawings and product data for cabinets.
- .2        Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3        Provide drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.

## **PART 2 PRODUCTS**

### **2.1            SPLITTERS**

- .1        Sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2        Main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3        At least three spare terminals on each set of lugs in splitters less than 400 A.

### **2.2            JUNCTION AND PULL BOXES**

- .1        Welded steel construction with screw-on flat covers for surface mounting.
- .2        Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

## **2.3 CABINETS**

- .1 Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.
- .2 Type T: sheet steel cabinet, with hinged door, latch, lock, 2 keys, containing 19 mm fir plywood backboard for surface flush mounting.

## **PART 3 EXECUTION**

### **3.1 SPLITTER INSTALLATION**

- .1 Install splitters and mount plumb, true and square to the building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

### **3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor.
- .3 Install terminal block as indicated in Type T cabinets.
- .4 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

### **3.3 IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name voltage and phase.

**END OF SECTION**