


PANEL SCHEDULE

LOCATION
 PANEL A
 TYPE 42 CIRCUIT SURFACE CABINET - TOP ENTRY
 RATING 120/208V, 3PH, 4W, 200 AMP, 4/4 200A MAIN BREAKER
 STANDARD OF ACCEPTANCE EATON POW-S-LINE 19
 MINIMUM INTERRUPTING CAPACITY 10000 R.M.S. SYMM AMPERES


CIRCUIT DESCRIPTION	LOAD AMP	LOAD WATT	LOAD VA	LOAD KVA	LOAD KW	LOAD KVA	CIRCUIT DESCRIPTION
RECEPT. 1 RECEPTACLE 1	2880	6	30	1.2	30	9	RECEPT. 1 RECEPTACLE 2
RECEPT. 1 RECEPTACLE 3	2880	6	30	1.2	30	9	RECEPT. 1 RECEPTACLE 4
RECEPT. 1 RECEPTACLE 5	1440	10	15	5	6	12	RECEPT. 2 RECEPTACLE 6
RECEPT. 2 RECEPTACLE 7	2880	6	30	1.2	30	9	RECEPT. 2 RECEPTACLE 8
RECEPT. 2 RECEPTACLE 9	2880	6	30	1.2	30	9	RECEPT. 2 RECEPTACLE 10
RECEPT. 3 RECEPTACLE 11	2880	4	30	11.2	30	4	RECEPT. 3 RECEPTACLE 12
RECEPT. 3 RECEPTACLE 13	2880	4	30	13.14	30	4	RECEPT. 3 RECEPTACLE 14
RECEPT. 3 RECEPTACLE 15	1440	6	15	15.16	15	6	RECEPT. 4 RECEPTACLE 16
RECEPT. 4 RECEPTACLE 17	2880	4	30	17.18	30	4	RECEPT. 4 RECEPTACLE 18
RECEPT. 4 RECEPTACLE 19	2880	4	30	19.20	30	4	RECEPT. 4 RECEPTACLE 20
LOADS 1,2,3,4	600	12	15	21.22	15	12	
			30	23.24			5000 STRIP HEATER
			28	26	3		MULTIBANK RECEPTACLE
			30	29	30	15	1000 ENCLOSURE LIGHT
			30	31	32	15	
			30	33	34		
			30	35	36		
			30	37	38		
			39	40			
			41	42			

1. PROVIDE TYPE WRITTEN DIRECTORY.
 PANEL BOARD TO BE C/W GROUNDED NEUTRAL, GROUND AND NEUTRAL BLOCKS, BOLT-ON TYPE BREAKERS WITH AN I.C. RATING AS INDICATED. RMS SYMMETRICAL AND ASYM METRICAL SHORT CIRCUIT CURRENTS TO BE INDICATED. ALL PANELS TO BE PROVIDED WITH WRITTEN DIRECTORY AND LOCKING DOOR. ALL PANELS TO BE RATED ALIKE. INSTALLATION, INCLUDING CONDUITS, TO BE RATED FOR SURFACE MOUNTED OVERHEAD APPLICATIONS. WALL MOUNT ON 19mm THICK, FENWOOD BRICKWORK FINISH WOOD LIGHT GRAY.




JIB CRANE CONDUIT LOCATION
 N.T.S. E1

NOTE:
 IMPROPERLY THAT BOLT NUTS ARE GENERATED WITHIN THE PANEL AS SHOWN.
 50mm ELECTRICAL CONDUIT STUBBED UP FOR FUTURE JIB CRANE (COILING)
 WHARF FACE




EMPTY CONDUIT FOR FUTURE ELECTRICAL EQUIPMENT
 N.T.S. E3

NOTE:
 THIS DETAIL IS FOR ALL ELECTRICAL LIGHT POLES, PERESTALS, AND FUTURE JIB CRANE AND PREVENT DAMAGE TO CONDUITS AND TO PREVENT ANY WATER OR DIRT TO ENTER THE CONDUIT THE EXACT LOCATION IS TO BE DETERMINED IN THE FIELD.
 GALVANIZED STEEL PIPE CAP WITH 6mm HOLE FOR PROTECTION FOR 50mm PVC CONDUIT FOR FUTURE JIB CRANE (COILING)
 4 - 6mm ϕ HULTI RHW-BOLTS
 100
 175
 150
 53mm ϕ PVC 90° ELBOW
 50mm ϕ PVC CONDUIT
 C/W POLY FISH COBOD
 WHARF DECK
 JOINER REINFORCEMENT
 DECK REINFORCEMENT



TRENCH DETAIL
 N.T.S. E2

NOTE:
 100mm GRANULAR BASE
 50mm WIRE YELLOW WRAPPING TAPE RANNING FULL LENGTH OF TRENCH. OPEN WILL BE 300mm BELOW 300mm GRANULAR SUBBASE
 PROVIDE 150mm CONCRETE COVERAGE ALL AROUND CONDUIT.
 1. 1.83mm PVC CONDUIT C/W 4 #1/4 W/40 TO ELECTRICAL PANEL.



OWNER'S POLE SERVICE DETAIL
 N.T.S. E4

NOTE:
 NEW 9M POLE
 OVERHEAD SERVICE CONDUCTORS TO BE MINIMUM OF 5M A.T.S.
 TWO HOLE PVC STRAPS (TYP)
 NEW OVERHEAD SERVICE SPOOL FOR CONDUCTORS.
 NEW METER BASE AND METER
 6mm ALUMINUM CONDUIT GUARD FROM GROUND UP TO 1500mm, FASTENED TO POLE WITH 50mm GALVANIZED PVC STRIPS
 CONCRETE AROUND CONDUIT
 FINISHED GRADE
 ALLOW 2M OF CONDUIT FOR CONNECTION TO UTILITY.

- GENERAL NOTES**
1. ALL ELEVATIONS ARE IN METRES UNLESS OTHERWISE NOTED.
 2. ALL DIMENSIONS ARE IN METRES UNLESS OTHERWISE NOTED.
 3. ALL WORK TO BE COMPLETED AS PER CANADIAN ELECTRICAL CODE C22.1-12

Province of Newfoundland and Labrador
 Public Works and Transportation
 Construction Services
 Canada

PROVINCE OF NEWFOUNDLAND AND LABRADOR
 PERMIT HOLDERS
 THIS PERMIT ALLOWS
MADERRA ENGINEERING
 To practice Professional Engineering
 Permit No. 98 issued by PEO 2005
 which is valid for the year 2015

REGISTERED PROFESSIONAL ENGINEER
 JOHN T. MADERRA
 15/07/09

STAFF

designer	designer
checked	checked
approved	approved

PROJECT
WHARF RECONSTRUCTION PORT AU CHOIX, NL

DATE
 JANUARY 2015

PROJECT NO.
R075163.001

NO. DU DESSIN
E3