

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Palace Grand Theatre Foundation Rep	
Solicitation No. - N° de l'invitation EZ899-152418/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client	Date 2015-07-20
GETS Reference No. - N° de référence de SEAG PW-\$PWY-022-7522	
File No. - N° de dossier PWY-5-38030 (022)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-07-24	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Arthur (PWY), Carolyn	Buyer Id - Id de l'acheteur pwy022
Telephone No. - N° de téléphone (604) 775-6667 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Palace Grand Theatre - Dawson City, YT	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-152418/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

009

File No. - N° du dossier

PWY-5-38030

Buyer ID - Id de l'acheteur

pw022

CCC No./N° CCC - FMS No/ N° VME

Amendment 009

Amendment 009 has been raised to:

- 1) incorporate Addendum No. 5.
- 2) revise the insurance requirements.

1) Addendum:

See the attached Addendum No. 5.

2) Insurance Requirements:

DELETE the requirement for Environmental Impairment Liability Insurance GC2040C (2014-06-26), Contractors Pollution Liability - Type 2.

See the attached revised insurance certificate.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

This Addendum contains 1 page.

QUESTIONS AND RESPONSES TO BIDDER'S QUERIES:

QUESTION:

Drwg S-3 indicates a maximum offset of 900 mm from the existing building exterior. Please confirm if the "building exterior" dimension includes the width of the roof soffit overhang along the perimeter of the building?
If the dimension does not include the width of the soffit, the access to the centre of the piles is diminished.

RESPONSE:

The maximum offset of 900mm from the existing building exterior is referring to the offset from the face of building exterior walls.

QUESTION:

Will the Owner please consider the increasing the offset from the exterior of the building (shown as maximum 900 mm on Drwg S3) to the centre the 350 mm steel pipe piles on the building perimeter? If so, what is the maximum increase in the offset from the building exterior?

We are requesting an increase in the offset dimension to allow access for drill rigs that are a minimum width of 2.6 m. The access to the centerline of the piles on the exterior of the theatre building on the east wall is also restricted by the existing building structures that are as close as 8.55 m.

Several models of the drills with the capacity to drill the 450 mm diameter exterior pile holes are mounted on mobile platforms that exceed a width of 2550 mm. These drills cannot actually fit over the plan locations of the piles given the current offset. There is no drill rig that we are aware of that could fit over the plan pile locations given the current offset.

What is the maximum offset off the pile locations?

Will the design allow for an offset of 1.7 m offset from the existing building? (This will account for the soffit overhang and the centerline of the drill to access the centerline of the 450 mm holes required for the installation of the 350 mm steel pipe piles.

RESPONSE:

The tender submission shall be based on the specified maximum offset of 900mm.

END OF ADDENDUM NO. 5

CERTIFICATE OF INSURANCE



Travaux publics et
Services gouvernementaux
Canada

Public Works and
Government Services
Canada

Description and Location of Work Palace Grand Theatre Foundation Replacement Dawson City, Yukon	Contract No.
	Project No. R.068835.001

Name of Insurer, Broker or Agent	Address (No., Street)	City	Province	Postal Code
----------------------------------	-----------------------	------	----------	-------------

Name of Insured (Contractor)	Address (No., Street)	City	Province	Postal Code
------------------------------	-----------------------	------	----------	-------------

Additional Insured
Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services

Type of Insurance	Insurer Name and Policy Number	Inception Date D / M / Y	Expiry Date D / M / Y	Limits of Liability		
				Per Occurrence	Annual General Aggregate	Completed Operations Aggregate
Commercial General Liability Umbrella/Excess Liability				\$	\$	\$
Builder's Risk / Installation Floater				\$		

I certify that the above policies were issued by insurers in the course of their Insurance business in Canada, are currently in force and include the applicable insurance coverage's stated on page 2 of this Certificate of Insurance, including advance notice of cancellation / reduction in coverage.

Name of person authorized to sign on behalf of Insurer(s) (Officer, Agent, Broker)

Telephone number

Signature

Date D / M / Y

General

The insurance policies required on page 1 of the Certificate of Insurance must be in force and must include the insurance coverage listed under the corresponding type of insurance on this page.

The policies must insure the Contractor and must include Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services as an additional Insured.

The insurance policies must be endorsed to provide Canada with not less than thirty (30) days notice in writing in advance of a cancellation of insurance or any reduction in coverage.

Without increasing the limit of liability, the policies must protect all insured parties to the full extent of coverage provided. Further, the policies must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.

Commercial General Liability

The insurance coverage provided must not be substantially less than that provided by the latest edition of IBC Form 2100. The policy must either include or be endorsed to include coverage for the following exposures or hazards if the Work is subject thereto:

- (a) Blasting.
- (b) Pile driving and caisson work.
- (c) Underpinning.
- (d) Removal or weakening of support of any structure or land whether such support be natural or otherwise if the work is performed by the insured contractor.

The policy must have the following minimum limits:

- (a) **\$5,000,000** Each Occurrence Limit;
- (b) **\$10,000,000** General Aggregate Limit per policy year if the policy contains a General Aggregate; and
- (c) **\$5,000,000** Products/Completed Operations Aggregate Limit.

Umbrella or excess liability insurance may be used to achieve the required limits.

Builder's Risk / Installation Floater

The insurance coverage provided must not be less than that provided by the latest edition of IBC Forms 4042 and 4047.

The policy must permit use and occupancy of any of the projects, or any part thereof, where such use and occupancy is for the purposes for which a project is intended upon completion.

The policy may exclude or be endorsed to exclude coverage for loss or damage caused by asbestos, fungi or spores, cyber and terrorism.

The policy must have a limit that is **not less than the sum of the contract value** plus the declared value (if any) set forth in the contract documents of all material and equipment supplied by Canada at the site of the project to be incorporated into and form part of the finished Work. If the value of the Work is changed, the policy must be changed to reflect the revised contract value.

The policy must provide that the proceeds thereof are payable to Canada or as Canada may direct in accordance with GC10.2, "Insurance Proceeds" (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2900D/2>).