



## Q&A #1

Date: July 20, 2015

Project: London Paving Project

---

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided in amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

---

Q1: Will existing CB frames and grates be replaced?

A1: No.

Q2: Are we permitted to complete the project in 1 phase?

A2: Yes.

Q3: Limit of project at Sandford St.

A3: Match edge of street paving.

Q4: Could we increase the depth of HL-3 to 40mm?

A4: Yes. Amendment #3 to follow.

Q5: Are there any anticipated base repairs?

A5: No.

Q6: What is the elevation from top of Granular base to top of pipe for sub drain?

A6: Amendment #3 to follow.

Q7: Is the step joint required to be milled at entrance?

A7: Yes.

Q8: Is there insurance requires with bid submissions?

A8: See tender package requirements: Appendix F – Insurance Terms.

Q9: Is work required to be complete after hours or weekends?

A9: Amendment #3 to follow.

---

All other conditions and requirements remain unchanged.