

PART 1 - GENERAL

Not applicable.

PART 2 - PRODUCTS

- 2.1 EQUIPMENT
- .1 Fused Disconnect Switch: to Section 26 28 23 - Disconnect Switches - Fused and Non-Fused up to 1000 V rating as indicated.
 - .2 Panelboard Breaker Type: to Section 26 24 17 - Panelboard Breaker Type rating as indicated.
 - .3 Cabinet Type 'A' for Utility Revenue Metering, Junction Box, Pull box, Splitter Box: to Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets, size as indicated.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Install service equipment.
 - .2 Connect to incoming service.
 - .3 Connect to outgoing load circuits.
 - .4 Make grounding connections in accordance with Section 26 05 28 - Grounding - Secondary.
 - .5 Make provision for power supply authority's metering.