

PART 1 - GENERAL

- 1.1 PRODUCT DATA .1 Submit product data in accordance with Section 01 33 00 - Submittals.

PART 2 - PRODUCTS

- 2.1 DISCONNECT SWITCHES
- .1 Fusible disconnect switch in CSA Enclosure Type 1, size as indicated.
  - .2 Provision for padlocking in on-off switch position by three (3) locks.
  - .3 Mechanically interlocked door to prevent opening when handle in ON position.
  - .4 Fuses: size as indicated, Class J up to 600 Amp.
  - .5 Fuseholders: re-locatable and suitable without adaptors, for type and size of fuse indicated.
  - .6 Quick-make, quick-break action.
  - .7 ON-OFF switch position indications on switch enclosure cover.
- 2.2 EQUIPMENT IDENTIFICATION
- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Requirements.
  - .2 Indicate name of load controlling on size 4 nameplate.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Install disconnect switches complete with fuses.