

PART 1 - GENERAL

- | | | |
|---|----|---|
| <u>1.1 SHOP DRAWINGS
AND PRODUCT DATA</u> | .1 | Submit shop drawings and product data for cabinets in accordance with Section 26 05 00. |
|---|----|---|

PART 2 - PRODUCTS

- | | | |
|--|----|--|
| <u>2.1 JUNCTION
AND PULL BOXES</u> | .1 | Waterproof PVC junction boxes as noted on drawings. |
| | .2 | Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes. |
| | .3 | Boxes to be sized in accordance with the CEC Part 1 without use of box extensions. |
| | .4 | Other boxes as noted on drawings. |
| | .5 | All splitters, junction, pull boxes to be NEMA 4x rated. |

PART 3 - EXECUTION

- | | | |
|---|----|--|
| <u>3.1 JUNCTION
AND PULL
BOXES INSTALLATION</u> | .1 | Install junction/pull boxes where indicated. |
| <u>3.2 INSTALLATION</u> | .1 | Provide equipment identification in accordance with Section 26 05 00 - Common Work Requirements - Electrical |
| | .2 | Install size 2 identification labels indicating system name. |